



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street • P.O. Box 83720 • Boise, Idaho 83720-0098

Phone: (208) 287-4800 • Fax: (208) 287-6700 • Web Site: www.idwr.idaho.gov

C.L. "BUTCH" OTTER

Governor

GARY SPACKMAN

Director

February 18, 2013

CHRISTY LOU AWALT
PO BOX 392
SAN MIGUEL CA 93451

RE: Permit Nos. 37-21486 and 37-21828

Dear Ms. Awalt:

On August 20, 2012, I conducted a field examination for the permits listed above. The next step in the appropriation process is to issue water right licenses based on my findings. By issuing a license, the Idaho Department of Water Resources (IDWR) confirms the extent of development that has been established in compliance with the terms of the permits. A condition of permit 37-21486 states:

Prior to diversion of water under this right, the right holder shall install and maintain a measuring device and lockable controlling works of a type acceptable to the Department as part of the diverting works.

During the field examination it appears that there was no measuring device on the pipeline that provides water to the place of use for irrigation purposes. In order to issue a license, you must either submit documentation that the measuring device was installed the time of the field exam and that this condition has been complied with or install the measuring device as required on your permit as soon as possible. If you need to install a measuring device, please contact the watermaster for water district #130, Cindy Yenter at (208) 736-3033.

IDWR will hold further action on this permit for 60 days in order to allow you time to respond or install a measuring device. If a response is not received within 60 days, pursuant to Section 42-219(6), Idaho Code, we may issue an order voiding the permit.

If you have any questions regarding this matter you may contact me at 208/287-4944. Thank you for your attention to this matter.

Sincerely,

Cherie Palmer, Sr. Water Resource Agent
Water Allocation Bureau