

RECEIVED

JUN 05 2013

WATER RESOURCES
WESTERN REGIONSTATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
APPLICATION FOR PERMIT
To appropriate the public waters of the State of IdahoIdent. No. 63-33787

1. Name of applicant(s) Miyasako Farms, LLC Phone 208 337-3003
 Name connector (check one): ☐ and ☐ or ☐ and/or Dan's Cell 724-2225
 Mailing address: PO Box 1060 City Homedale
 State ID Zip 83628 Email: dan@pacificwindinc.com
2. Source of water supply Ground which is a tributary of _____
3. Location of point(s) of diversion:

Twp	Rge	Sec	Govt Lot	1/4	1/4	1/4	County	Source	Local name or tag #
<u>03N</u>	<u>04W</u>	<u>11</u>		<u>SE</u>	<u>SW</u>		<u>CANYON</u>	<u>Ground Water</u>	

4. Water will be used for the following purposes:

Amount 2.96 cfs for Irrigation purposes from 3/1 to 11/15 (both dates inclusive)
 (cfs or acre-feet per year)

Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
 (cfs or acre-feet per year)

Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
 (cfs or acre-feet per year)

Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
 (cfs or acre-feet per year)

5. Total quantity to be appropriated is (a) 2.96 cubic feet per second (cfs) and/or (b) _____ acre-feet per year (af).

6. Proposed diverting works:

- a. Describe type and size of devices used to divert water from the source. Drilled Well with Gravity Irrigation System
- b. Height of storage dam _____ feet; active reservoir capacity _____ acre-feet; total reservoir capacity _____ acre-feet. If the reservoir will be filled more than once each year, describe the refill plan in item 11.
 For dams 10 feet or more in height OR reservoirs with a total storage capacity of 50 acre-feet or more, submit a separate Application for Construction or Enlargement of a New or Existing Dam. Application required? ☐ Yes ☐ No
- c. Proposed well diameter is 16" inches; proposed depth of well is 500 feet.
- d. Is ground water with a temperature of greater than 85°F being sought? ☐ Yes ☒ No
- e. If well is already drilled, when? _____; drilling firm _____;
 Well was drilled for (well owner) WATER Right 63-11220; Drilling Permit No. D0064436

7. Description of proposed uses (if irrigation only, go to item 8):

- a. Hydropower; show total feet of head and proposed capacity in kW. _____
- b. Stockwatering; list number and kind of livestock. _____
- c. Municipal; show name of municipality or the applicant's qualifications as a municipal provider. _____
- d. Domestic; show number of households _____
- e. Other; describe fully. _____

8. Description of place of use:

- a. If water is for irrigation, indicate acreage in each subdivision in the tabulation below.
- b. If water is used for other purposes, place a symbol of the use (example: D for Domestic) in the corresponding place of use below. See instructions for standard symbols.

TWP	RGE	SEC	NE				NW				SW				SE				TOTALS
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
03N	04W	11									36								36
03N	04W	11								37									37
03N	04W	11					38												38
03N	04W	11															37		37

Total number of acres to be irrigated: 148

9. Describe any other water rights used for the same purposes as described above. Include water delivered by a municipality, canal company, or irrigation district. If this application is for domestic purposes, do you intend to use this water, water from another source, or both, to irrigate your lawn, garden, and/or landscaping? Wilder Irrigation District and Nampa Meridian Irrigation District.
10. a. Who owns the property at the point of diversion? Miyasako Farms LLC
b. Who owns the land to be irrigated or place of use? PLA's Per Agreement
c. If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing: _____
11. Describe your proposal in narrative form, and provide additional explanation for any of the items above. Attach additional pages if necessary. Miyasako Farms has a long term lease with John PLA's.
12. Time required for completion of works and application of water to proposed beneficial use is 5 years (minimum 1 year).
13. **MAP OF PROPOSED PROJECT REQUIRED** - Attach an 8½" x 11" map clearly identifying the proposed point of diversion, place of use, section #, township & range. A photocopy of a USGS 7.5 minute topographic quadrangle map is preferred.

The information contained in this application is true to the best of my knowledge. I understand that any willful misrepresentations made in this application may result in rejection of the application or cancellation of an approval.

Dani Miyasako
Signature of Applicant


DANI MIYASAKO
Print Name (and title, if applicable)

Signature of Applicant

Print Name (and title, if applicable)

For Department Use:

Received by JA Date 6/5/2013 Time 3:15 Preliminary check by SL
Fee \$ 330.00 Receipted by JA Receipt No. W041195 Date 6/5/2013



Sommer, Rachel

From: Sommer, Rachel
Sent: Thursday, June 13, 2013 12:32 PM
To: 'LEGALS@IDAHOPRESS.COM'
Subject: Legal Ad
Attachments: Canyon Cover Letter.docx; Canyon Legal Ad.docx

Good Afternoon Leann Nobella,

Please see the attached ad for publication on 6/20/2013 & 6/27/2013.

Please confirm these are okay to publish as shown.

Thank you very much,

Rachel Sommer

Administrative Assistant
IDWR, Western Region
Office: 208-334-2190
Fax: 208-334-2348
rachel.sommer@idwr.idaho.gov

June 13, 2013

LEGAL NOTICE DEPARTMENT
PRESS TRIBUNE
PO BOX 9399
NAMPA, ID 83652

RE: Application For Permit No's: 63-33761, 63-33779 & 63-33787.

Dear Legal Notice Department:

Please publish the enclosed legal notice on the dates indicated (once a week for two consecutive weekly issues). If you cannot publish the notice on the proposed dates, please contact us immediately.

An affidavit of publication must be submitted to the Department along with the publication bill. Please send the affidavit and bill to this office before 7/8/2013. Your cooperation is appreciated.

Sincerely,

Rachel Sommer
Administrative Assistant

Enclosures

The following applications have been filed to appropriate the public waters of the State of Idaho:

63-33761

RUBEN ASUMENDI
DOMINGO ASUMENDI

23032 HWY 20 26

PARMA, ID 83660

Points of Diversion NESE SENE S23 T05N R04W CANYON County Source GROUND WATER

Point of Diversion L1(NWNW) S30 T05N R03W CANYON County Source GROUND WATER

Point of Diversion NENE S25 T05N R04W CANYON County Source GROUND WATER

Use: IRRIGATION 03/01 to 11/15 2 CFS

Total Diversion: 2 CFS

Date Filed: 4/18/2013

Place Of Use: IRRIGATION

T05N R03W S30 L1(NWNW)

T05N R04W S22 NESW NWSW

T05N R04W S23 SENE NESE

T05N R04W S25 NENE NWNE NENW

Total Acres: 295

Water bearing zone to be appropriated is from 20 to 300 feet.

63-33779

DEL MONTE MEAT CO INC

21696 STATELINE RD

WILDER, ID 83676

Point of Diversion L1(NWNW) S14 T04N R06W CANYON County Source ALLEN DRAIN Tributary SNAKE RIVER

Use: IRRIGATION 03/01 to 11/15 1.04 CFS

Use: STOCKWATER 01/01 to 12/31 0.24 CFS

Total Diversion: 1.28 CFS

Date Filed: 5/17/2013

Place Of Use: IRRIGATION & STOCKWATER

T04N R06W S14 NENW L1(NWNW) L2(SWNW) SENW

Total Acres: 52

63-33787

MIYASAKO FARMS LLP

PO BOX 1060

HOMEDALE, ID 83628-1060

Point of Diversion SESW S11 T03N R04W CANYON County Source GROUND WATER

Use: IRRIGATION 03/01 to 11/15 2.96 CFS

Total Diversion: 2.96 CFS

Date Filed: 6/5/2013

Place Of Use: IRRIGATION

T03N R04W S11 NENW SENW NESW SWSE

Total Acres: 148

Water bearing zone to be appropriated is from 230 to 500 feet. This well currently being drilled as replacement well for right 63-11220, well will be used for supplemental irrigation under 63-11220 & this application.

Permits will be subject to all prior water rights. For additional information concerning the property location, contact Western Region office at (208) 334-2190; or for a full description of the right(s), please see www.idwr.idaho.gov/apps/ExtSearch/WRFiling.asp. Protests may be submitted based on the criteria of Idaho Code § 42-203A. Any protest against the approval of this application must be filed with the Director, Dept. of Water Resources, Western Region, 2735 Airport Way, Boise ID 83705 together with a protest fee of \$25.00 for each application on or before 7/8/2013. The protestant must also send a copy of the protest to the applicant.

GARY SPACKMAN, Director

Published on 6/20/2013 and 6/27/2013



State of Idaho

DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way, Boise, Idaho 83705-5082

PHONE: (208) 334-2190 FAX: (208) 334-2348 www.idwr.idaho.gov

C.L. "BUTCH" OTTER, Governor

GARY SPACKMAN, Director

June 10, 2013

MIYASAKO FARMS LLP
PO BOX 1060
HOMEDALE ID 83628

Re: Application for Permit No. 63-33787

Dear Applicant:

The above referenced application for a supplemental irrigation well is being expedited as noted in the email sent to you earlier today in which identification of the water bearing zone was requested.

While the legal notice process is running, please submit additional information as outlined below to provide the Idaho Department of Water Resources (IDWR) details needed to fully evaluate your application.

The application requests 2.96 cfs from a replacement well currently being drilled under right 63-11220. That right authorizes 0.54 cfs. The IDWR field exam for 63-11220 documented a diversion capacity from the original well located nearby for 2.60 cfs. The sum of the old right and the new application is 3.50 cfs. Based on the prior information for the original irrigation well, it appears water availability is probably sufficient for your proposed use.

However, increased ground water pumping raises potential injury issues for this site. Please see the enclosed map illustrating numerous wells surrounding your irrigation well site. Most if not all of the green dots are domestic wells, while the orange squares represent water right points of diversion. Please provide information that increased pumping will not injure wells within about a one mile radius from the SESW Section 11 site. This analysis should discuss impacts from your proposed rate of flow and impacts from an estimated annual volume probably needed for supplemental use. IDWR recognizes rate and annual volume for this use are highly variable but some rough idea of your need probably can be determined. Please see the enclosed consultant list that might be helpful due to the technical nature of this request.

Please submit the information for application processing to be completed. You may seek additional time to respond by making a written request to interrupt processing for up to six months. The application will be voided without a timely written reply within the next sixty (60) days.

Application 63-33787

June 10, 2013

Page 2

Refunds are not issued for voided applications.

IDWR forms and other information are available on the Internet at www.idwr.idaho.gov. Please contact me at 208-334-2190 if you need more information. Thank you for your attention to these matters.

Sincerely,




Steve Lester

Water Rights Supervisor

Enclosure: Site Map
 Consultant List

→ cc not attached for file
since readily available

2011 PHOTO



Legend

Sections

QQ

Active Water Right POD

Wells

- mostly wells



□ APPLICATION well $\frac{1}{4}$ $\frac{1}{4}$

Lester, Steve

From: Dan Miyasako [dan@pacificwindinc.com]
Sent: Monday, June 10, 2013 1:12 PM
To: Lester, Steve
Subject: Re: Supplemental well water right application

Steve,

It looks like 231 feet to 500 feet.

Sent from Dan's iPhone.

On Jun 10, 2013, at 9:27 AM, "Lester, Steve" <Steve.Lester@idwr.idaho.gov> wrote:

Dan:

Your application to use the replacement well (now being drilled for right 63-11220) for another 148 acres is being expedited. This Wednesday we send legal notices to the *Press Tribune* for publication the 3rd & 4th weeks of June. In order to publish the legal notices we need to complete this sentence that will be part of the notice: water bearing zone to be appropriated is from ___ to ___ feet.

Since we do not yet have a well log to get this information, please consult with your driller to provide this information no later than this Wednesday, June 12, in order to meet the earliest possible legal notice deadline. Otherwise we won't be able to publish until the 1st two weeks of July at the earliest.

Thank for your prompt attention to this & please let me know if you have any questions.

Steve Lester
Water Rights Supervisor
IDWR Western Region
208-334-2190

Lester, Steve

From: Dan Miyasako [dan@pacificwindinc.com]
Sent: Monday, June 10, 2013 1:45 PM
To: Lester, Steve
Subject: Fwd: Drillers Log
Attachments: Miyasako's drilling log.pdf; ATT00001.htm

Steve,

Attached is the well log and casing plan which has been approved by Sonny. We are setting casing today.

Sent from Dan's iPhone.

Begin forwarded message:

From: Cody Daugherty <cody@rsicorp.net>
Date: June 6, 2013, 4:02:26 PM MDT
To: Dan Miyasako <dan@pacificwindinc.com>
Subject: Drillers Log

Dan,

Attached is the log for your well and our well design. We plan on setting casing this coming Monday and off the hole a few days after that.

If you have any questions please call.

Thanks,

--

Cody Daugherty
Drilling Manager
Riverside Inc.
Cell: (208) 870-7913
Office: (208) 722-6731

Customer Danny Misako
 Address 1415 Kamei (Hunting)
 Driller Justin Clavel
 Hole Size 14/24 " Casing Size 16 "
 Screens or Perforations 5/8 Screen



Date Started May 24, 2013
 Date Completed May 31, 2013
 Helper Alvin Taylor Drill Used Challenger
 Water Level at 3:30

Formation

Time	Stem #	Depth		Formation
		From	To	
May 27	0		3	Top Soil
	3		32	Clay (Hard Pan)
	32		35	Brown Sand & Fine Rock
	35		53	Clay (Hard Pan) streaked Sandstone & River Rock 44'
	53		55	Brown Siltsburg
	55		59	White Ash
	59		69	Brown Clay
	69		76	Brown Sand & River Gravel
	76		78	Red Brown Clay
	78		84	Med to Fine Brown Sand
	84		90	Coarse to Fine Brown Sand w/ Pe Gravel
	90		93	Brown Clay
	93		96	Fine Brown Sand
	96		115	Coarse Brown Sand w/ River rock (lost water)
May 30	115		120	Brown Clay (streaky)
May 31	120		129	" " (sand streak 126')
	129		135	Med to Fine Brown Sand (clay streak 134' 150)
	135		138	~~Brown Clay (streaky)~~
	138		155	~~Brown Clay (streaky)~~
	155		160	Brown Clay
	160		169	Blue Clay
	169		173	Fine Blue Sand
	173		185	Blue Clay (streaky)
	185		195	" " "

Customer David Mysko
 Address Blue & White (Hudson)
 Driller Justin Clavel
 Hole Size 14/24 " Casing Size 16 "
 Screens or Perforations 53 Screens



Date Started May 24, 2013
 Date Completed May 24, 2013
 Helper Adam Fugate
 Drill Used Challenger
 Water Level at 53

Formation

Time	Stem #	Depth		Formation
		From	To	
5'	<	195	215	Fine to Med Blue Sand
		215	251	Coarse to Fine Blue Sand
		251	263	Blue Clay
	8' <	263	271	Fine to Med Blue Sand (clay streak 263 to 269)
		271	292	Grey Clay
	5' <	292	297	Med to Fine Blue Sand
		297	312	Blue Clay
17'	<	312	329	Med to Coarse Blue Sand (clay streak 319)
		329	332	Grey Clay
	11' <	332	343	Fine to Med Blue Sand
		343	347	Grey Clay
		347	353	Fine Blue Sand
	45' <	353	365	Med to Fine Blue Sand
		365	392	Fine to Coarse Blue Sand w/ thin clay streaks
		392	400	Grey Clay
Sum 3		400	422	11" n' (sand streak 407 to 412) 416
	4' <	422	426	Med to Fine Blue Sand
		426	430	Grey Clay
	16' <	430	440	Fine Blue Sand
		440	445	Grey Clay
	2' <	445	447	Fine Blue Sand
		447	452	Grey Clay



Riverside Inc.

[illegible]

Miyasako Farms

16" casing - 378'

16" stainless - 120'

