

Kidman, Denise

To: Lori Graves
Subject: RE: IDFG Xfer

From: Lori Graves [<mailto:LGraves@spfwater.com>]
Sent: Friday, January 18, 2013 7:15 AM
To: Kidman, Denise
Subject: RE: IDFG Xfer

The existing home and office are being demolished.

From: Lori Graves [<mailto:LGraves@spfwater.com>]
Sent: Thursday, January 17, 2013 1:56 PM
To: Kidman, Denise
Subject: RE: IDFG Xfer

Denise,

Typical in-home use for a residence is 250 gpd. We anticipate similar or less use at the office. Therefore, total indoor use should be less than 1000 gpd.

Irrigation will occur around the homes within a very small footprint. The total irrigated area will be less than ½ acre. Irrigation demand for ½ acre should be less than 6500 gpd (i.e., one inch x ½ acre). Therefore, we anticipate that total daily use will be less than 7500 gpd. Staying under the 13,000 gpd limit should not be a challenge.

Please let me know if I can provide anything else. Thanks Denise.

From: Kidman, Denise [<mailto:Denise.Kidman@idwr.idaho.gov>]
Sent: Wednesday, January 16, 2013 3:28 PM
To: Lori Graves
Subject: RE: IDFG Xfer

Lori,

I am working on the approval of this transfer and have a question about the map with the application (attachment 7A). I looked back at my emails and my notes but can't find anything. It looks like IDFG is removing the domestic right from the 'current domestic use' to the three new homes and office. Is that right? If so, what will be the source for the existing home and/or buildings?

Right 35-11394 was decreed in the SRBA for one home (see attachment). Now the use is going to increase by two homes and an office. Can you find out how they determined how they would not exceed the 13,000 gpd? Part of the approval process is that I have to look into enlargement issues. Any information you can get will help me get this approved.

Thanks,

Denise Kidman