

MEMORANDUM

TO: File 63-31362
FROM: Monica Van Bussum
DATE: November 9, 2012
RE: Licensing 63-31362

This memo serves to document some of the decisions I made while licensing 63-31362.

Contacts: Centers Construction Co. Contact listed as permitted.

Source/POD: Permitted for 1 point of diversion (POD) in Township 3 North, Range 1 West, Section 5 NWSW. Field exam found 2 PODs.

The permit holder paid a \$50 permit amendment fee under receipt W034982.

Water Use: Field exam confirmed the use is for potable use only on the lots in the subdivision as permitted.

Quantity: Permitted for 0.24 cfs and the licensing field exam found a capacity well in excess of the permitted amount (1.34 cfs). Licensed as permitted. There are no overlapping rights on these PODs.

POU: I selected the taxlots out of IDWR's Canyon County taxlot layer to use as the POU. Field exam confirmed use on the 31 lots as permitted.

Other comments: The permit was issued for a water development zone of 90 to 150 feet. That zone was later amended to 90 to 240 feet by Shelley Keen in a memo to the file on July 26, 2002. The applicants met the amended condition, but the condition is no longer required for permits of this kind and thus no need to continue with the condition on the water right.