



State of Idaho

DEPARTMENT OF WATER RESOURCES

Western Region, 2735 Airport Way • Boise, Idaho 83705-5082

Phone: (208) 334-2190 • Fax: (208) 334-2348 • Web Site: www.idwr.idaho.gov

November 23, 2011

C. L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Interim Director

JOHN WEBSTER
4090 PINOAK CT
BOISE ID 83705

COPY

RE: 63-11334 PERMIT SUBJECT TO LICENSING FOR TWIN PINES WATER USERS ASSN

Dear John

Department records show Michael Ashby as the contact person for the subdivision, however in reviewing the tax lot information I see that he no longer owns any of the lots covered by the permit. As you have a Boise address I have started with you in an effort to determine who the representative should be.

Some information has been gathered in an effort to complete the licensing process; however I want to confirm some of the information and possibly obtain some additional information to complete that process.

The clip to the right shows an aerial view of the permitted Place of Use (POU) for your convenience.



You can reach me at 208-334-2190 (ask for Kelly) and we can discuss the permit and the licensing process in greater detail.

You may also reach me by e-mail at the address shown below.

Sincerely

Kelly K Christensen
Sr Water Resource Agent
Western Region
e-mail address kelly.christensen@idwr.idaho.gov

PERMIT 63-11336 PRE LICENSE REVIEW

The system is a buried spring box and buried mainline to a 10,000 gal storage tank and then continuing underground easterly to then swing northerly through the Twin Pine Subdivision to eventually reach the POU for 63-2025 and 63-15180. Remarks for the two decreed rights state that they share the same POD.

63-02025 is decreed for a POD in Sec 31 NESW:
63-15180 is decreed for a POD in Sec 31 SWSW

Arc Map point is in Sec 31 NESW
Arc Map point is in Sec 31 SESW

As of 11-30-2011 information provided identifies that lots 1 thru 7 and lot 12 of the Twin Pine Subdivision either have homes hooked to the system or the lots have a 'stubbed in' connection for that lot use. An agreement was apparently drafted and possibly signed recognizing that 63-2025 and 63-15180 have an earlier priority date and that the subdivision use shall not interfere with their use.

Permit 63-11336 identifies both the POD and POU as being in Sec 31 NESW however the POD as found is in Sec 31 SWSW and the 8 subdivision lots are all in Sec 31 SESW.