

[illegible]

D. FLOW MEASUREMENTS

Measurement Equipment	Type	Make	Model No.	Serial No.	Size	Calibration Date
N/A						

Measurements N/A

E. NARRATIVE/REMARKS/COMMENTS

DOMESTIC USE: Assessor information per ArcMap photo (Bing), tax lot research, email, confirmed dwelling on site for identified owner.

Couldn't find a well log specific to this property but a map attached to the application Mr Stradley indicated a well on the property. I emailed Mr. Stradley and there is no well tag on his well.

Have conditions of permit approval been met? ☒ Yes ☐ No

F. FLOW CALCULATIONS

Measured Method: ☐ Additional Computation Sheets Attached
ALLOW PERMIT RATE

G. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation: N/A
 $VI.R. = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$
 $VD.R. = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigations Season}) \times 1.9835 =$
 $V = \text{Smaller of VI.R. and VD.R.} =$

2. Volume Calculations for Other Uses: ALLOW
1.2 AF
for
domestic

H. RECOMMENDATIONS

1. Recommended Amount

BENEFICIAL USE	PERIOD OF USE		RATE OF DIVERSION ANNUAL	
	From	To	Q(cfs)	V(afa)
DOMESTIC	01/01	12/31	0.04	1.20

TOTALS 0.04 1.20

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None
☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name Jean Hersley
Reviewer

Date 7/13/2012
Date



Identify

Identify from: Taxlots

Taxlots

STRADLEY DAVID RUSSELL

Location:

2,295,679.608 1,705,798.820 Meters

Field	Value
ID	659738
UPDATED	1/13/2012
PIN	RP37N03W262250
OWNER	STRADLEY DAVID RUSSELL
ADDRESS1	18473 BITTERROOT LN
ADDRESS2	
CITY	JULIAETTA
STATE	ID
ZIPCODE	83535
P_ADDRESS	18473 BITTERROOT LN
P_ZIPCODE	83535
SUB_NAME	
LEGAL1	721.0-000.00
LEGAL2	#8135 SENE 26 37 3W
LEGAL3	
LEGAL4	
LEGAL5	
LEGAL6	<null>
ACRES	4.9
COUNTY	Nez Perce
SOURCE	<null>
YEAR_BUILT	2000

Identified 1 Feature

RECEIVED

Form 238-7

3/95 JUN 30 1998

IDAHO DEPARTMENT OF WATER RESOURCES

WELL DRILLER'S REPORT

Use Typewriter or Ballpoint Pen

NORTHERN REGION

IDWR

1. DRILLING PERMIT NO. 86-98-N-31

Other IDWR No. D000 3368

2. OWNER:


Name Mike Axtell

Address 3307 Hawaii Rd

City Lewiston State ID Zip 83501

3. LOCATION OF WELL by legal description:

Sketch map location must agree with written location.



Twp. 37 North ☒ or South ☐
Rge. 3 East ☐ or West ☒
Sec. 26 NE 1/4 NW 1/4 SE 1/4 SW 1/4
Gov't Lot _____ County _____
Lat: _____ Long: _____

Address of Well Site 1/2 mile off Hubbard

City Juliette

Gukh Rd.

(Give at least name of road + Distance to Road or Landmark)

Lt. _____ Blk. _____ Sub. Name _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other _____

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other _____

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other _____

7. SEALING PROCEDURES

SEAL/FILTER PACK			AMOUNT		METHOD
Material	From	To	Sacks or Pounds		
Bentonite	0	58	135 lbs		Dry Pour

Was drive shoe used? ☒ Y ☐ N Shoe Depth(s) 58

Was drive shoe seal tested? ☒ Y ☐ N How? AIR

8. CASING/LINER:

Diameter	From	To	Gauge	Material	Casing	Liner	Welded	Threaded
8"	+2	58	025	3" x 1"	☒	☐	☒	☐
6"	-5	245		PVC	☐	☒	☐	☐

Length of Headpipe _____ Length of Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations Method Sk. 11 SW

☐ Screens Screen Type _____

From	To	Slot Size	Number	Diameter	Material	Casing	Liner
205	245	1/2"	40	6"	PVC	☐	☒

10. STATIC WATER LEVEL OR ARTESIAN PRESSURE:

125 ft. below ground Artesian pressure _____ lb.

Depth flow encountered 210 ft. Describe access port or

control devices: Removable Well Cap

37 N 3 W 26

FORWARD WHITE COPY TO WATER RESOURCES

Office Use Only

Inspected by _____

Twp _____ Rge _____ Sec _____

1/4 1/4 1/4

Lat: _____ Long: _____

11. WELL TESTS:

☐ Pump ☐ Bailor ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pumping Level	Time
50		235	1 hr.

Water Temp. 49°

Bottom hole temp. _____

Water Quality test or comments: Clean + Clean

Depth first Water Encountered 210

12. LITHOLOGIC LOG: (Describe repairs or abandonment)

Water

Bore Dia.	From	To	Remarks: Lithology, Water Quality & Temperature	Y	N
10"	0	2	OVER BORDEN		☒
10"	2	35	Schale		
10"	35	37	Basalt		
10"	37	45	Schale		
10"	45	58	Basalt		
8"	58	80	Schale		
8"	80	115	Basalt		
8"	115	135	Fract. Basalt		
8"	135	140	Basalt		
8"	140	225	Schale	☒	☒
8"	225	245	Basalt		☒

Completed Depth 245 (Measurable)

Date: Started 6-23-98 Completed 6-24-98

13. DRILLER'S CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name Baer's Well Drilling Firm No. 103

Firm Official G.R. Baer Date 6-24-98

and Supervisor or Operator [Signature] Date 6-24-98

(Sign once if Firm Official & Operator)