

Hemenway, Sandy

From: Ej Harpham [ejharpham@sitestar.net]
Sent: Thursday, April 19, 2012 3:00 PM
To: Hemenway, Sandy
Cc: Hemenway, Sandy
Subject: Re: 37-20746 Stark water right questions

Hi Sandy,

A quick call to Walker Water Sytem had all the answers!

It was in 1993 that the well was drilled for previous owner Doug Brock

I answered below in your e-mail. If you ever need that strong cup of tea or coffee for your drive home, stop on by.
ej

--- Sandy.Hemenway@idwr.idaho.gov wrote:

From: "Hemenway, Sandy" <Sandy.Hemenway@idwr.idaho.gov>
To: <ejharpham@sitestar.net>
Cc: "Hemenway, Sandy" <Sandy.Hemenway@idwr.idaho.gov>
Subject: 37-20746 Stark water right questions
Date: Thu, 19 Apr 2012 12:10:48 -0600

Hi E.J.,

Here are the questions that I have, in order to complete the licensing process:

- (1) What is the Horsepower of the submersible pump in the well? **2 Horse Power**
- (2) Do you know what the brand, model or serial number of the pump is? **Goulds #18E20412**
- (3) What is the discharge size off of the well? **1 1/4"**
- (4) Do you have a well drillers log for the well or know what the depth and static level are in the well?
Depth 310' Static 209'
- (5) What size and type of pipe goes from the well to the top of the stream, where it open discharges into the stream coming down into the pond? **2" Pipe, PVC Schedule 40**
- (6) I'm figuring the average depth of the pond is 5 feet, do you agree, or should it be different? It might be better to list deeper (at least **6'?**) as we have year round access to water below the freeze line.

Please return your answers by 5/2/2012, so I can complete the licensing process.

Thank you again for taking me around and showing me the water system, and your shop. I really appreciate it. I look forward to hearing from you soon.

Sandy Hemenway

Sr. Water Resource Agent
IDWR/State Office
PO Box 83720 or 322 E. Front St.