

77829

RECEIVED

MAR 15 2012

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCESIdent. No. 85-15743

APPLICATION FOR PERMIT

To appropriate the public waters of the State of Idaho

IDWR / NORTH

1. Name of applicant(s)
- McCann Land Company, Gary Snyder
- Phone
- 208.746.9494

Name connector (check one): ☐ and ☐ or ☒ and/orMailing address: 1824 17th Avenue City LewistonState Idaho Zip 83501 Email: _____

2. Source of water supply
- Springs
- which is a tributary of
- Sinks

3. Location of point(s) of diversion:

Twp	Rge	Sec	Govt Lot	1/4	1/4	1/4	County	Source	Local name or tag #
33N	03W	23	15	~~NW~~	~~SE~~	~~NE~~	Lewis County	Spring	Corral Pond
33N	03W	23	23	~~SE~~	~~NW~~	~~SW~~	Lewis County	Spring	Camp Pond

4. Water will be used for the following purposes:

Amount 4.0 AF for Stockwater Storage purposes from 1/1 to 12/31 (both dates inclusive)
(cfs or acre-feet per year)Amount 3.1 AF for Fire Protection Storage purposes from 1/1 to 12/31 (both dates inclusive)
(cfs or acre-feet per year)Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per year)Amount _____ for _____ purposes from _____ to _____ (both dates inclusive)
(cfs or acre-feet per year)

5. Total quantity to be appropriated is (a) _____ cubic feet per second (cfs) and/or (b)
- 4.0
- acre-feet per year (af).

6. Proposed diverting works:

a. Describe type and size of devices used to divert water from the source. There will be two small ponds fed by springs
Corral Pond ~ 75'x75'x10' (~1.3 acre feet of storage), Camp Pond ~ 60'x75'x10' (~1.1 acre feet of storage)b. Height of storage dam 0 feet; active reservoir capacity ~2.4 acre-feet; total reservoir capacity
2.4 acre-feet. If the reservoir will be filled more than once each year, describe the refill plan in item 11.For dams 10 feet or more in height OR reservoirs with a total storage capacity of 50 acre-feet or more, submit a separate
Application for Construction or Enlargement of a New or Existing Dam. Application required? ☐ Yes ☒ Noc. Proposed well diameter is N/A inches; proposed depth of well is N/A feet.d. Is ground water with a temperature of greater than 85°F being sought? ☐ Yes ☒ Noe. If well is already drilled, when? N/A; drilling firm N/A;
Well was drilled for (well owner) N/A; Drilling Permit No. N/A.

7. Description of proposed uses (if irrigation only, go to item 8):

a. Hydropower; show total feet of head and proposed capacity in kW. N/Ab. Stockwatering; list number and kind of livestock. Approximately 60 to 70 cow/calf pairs per yearc. Municipal; show name of municipality or the applicant's qualifications as a municipal provider. N/Ad. Domestic; show number of households N/Ae. Other; describe fully. Fire protection and stockwater uses.

85-15743

RECEIVED
MAR 15 2012

IDWR / NORTH

8. Description of place of use:

- If water is for irrigation, indicate acreage in each subdivision in the tabulation below.
- If water is used for other purposes, place a symbol of the use (example: D for Domestic) in the corresponding place of use below. See instructions for standard symbols.

TWP	RGE	SEC	NE				NW				SW				SE				TOTALS
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
33N	03W	23				S,F		S,F							S,F				
						L15		L23							L15				
						L16									L16				

Total number of acres to be irrigated: N/A

- Describe any other water rights used for the same purposes as described above. Include water delivered by a municipality, canal company, or irrigation district. If this application is for domestic purposes, do you intend to use this water, water from another source, or both, to irrigate your lawn, garden, and/or landscaping? Water Right 85-04182 applies in the NENE of Section 23 for stockwater but will remain unchanged.
- Who owns the property at the point of diversion? McCann Land Company
 - Who owns the land to be irrigated or place of use? McCann Land Company
 - If the property is owned by a person other than the applicant, describe the arrangement enabling the applicant to make this filing: N/A
- Describe your proposal in narrative form, and provide additional explanation for any of the items above. Attach additional pages if necessary. We propose to dig a pit/pond type depression at each of the above mentioned locations within Sec 23. The size and depth of the ponds are to allow for cattle water access, and helicopter dipping for fire protection. Both include evaporation at 36"/year on 10,125 ft2. Storage was estimated from pond dimensions and the volume was based on 12 gal per day per cow/calf pair over ~365 days for 70 pairs. The ponds will hold 1.1 to 1.3 AF of active storage and will fill from natural spring water which is estimated to be approximately 4.0 AF per year each.
- Time required for completion of works and application of water to proposed beneficial use is 3 years (minimum 1 year).
- MAP OF PROPOSED PROJECT REQUIRED** - Attach an 8½" x 11" map clearly identifying the proposed point of diversion, place of use, section #, township & range. A photocopy of a USGS 7.5 minute topographic quadrangle map is preferred.

The information contained in this application is true to the best of my knowledge. I understand that any willful misrepresentations made in this application may result in rejection of the application or cancellation of an approval.

McCann Land Company
By: Gary W. Snyder
Signature of Applicant

GARY W. SNYDER, PRESIDENT
Print Name (and title, if applicable)

Signature of Applicant

Print Name (and title, if applicable)

For Department Use:

Received by Dianne Date 3/26/12 Time _____ Preliminary check by _____
Fee \$ 100.00 Received by Dianne Receipt No. N089017 Date 3/26/12

Corral Pond


33N03W23NE E
LOT 1

Corral Pond New
Location

33N03W23SENE
LOT 15


33N03W23SENE
LOT 16

85-15743



Legend

-  workingpod
-  workingpou
-  QQ
-  Taxlots



MCCANN LAND COMPANY PONDS

RECEIVED
MAR 15 2012
IDWR / NORTH

Corral Pond: 75 FT X 75 FT X 10 FT = 56,250 CUFT = 1.3 AF
 Surface area: 75 FT X 75 FT = 5,625 SQFT
 Evaporation: 351 gpd x 365 days / 325,850 gal/af = 0.4 AF
 Seepage: Instream no seepage losses

Camp Pond: 60 FT X 75 FT X 10 FT = 45,000 CUFT = 1.1 AF
 Surface area: 60 FT X 75 FT = 4,500 SQFT
 Evaporation: 281 gpd x 365 days / 325,850 gal/af = 0.3 AF
 Seepage: Instream no seepage losses

Stockwater: 70 head of mixed x 12 gpd x 365 days / 325,850 gal/af = 0.9 AF

4.0 AF	Stockwater Storage	a.) Ponds Size	2.4 AF
		b.) Evaporation	0.7 AF
		c.) Seepage	0.0 AF
		d.) Stockwater	0.9 AF
	TOTAL		4.0 AF

3.1 AF	Fire Protection Storage	a.) Ponds Size	2.4 AF
		b.) Evaporation	0.7 AF
		c.) Seepage	0.0 AF
	TOTAL		3.1 AF

TOTAL STORAGE VOLUME 4.0 AF