



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street • P.O. Box 83720 • Boise, Idaho 83720-0098

Phone: (208) 287-4800 • Fax: (208) 287-6700 • Web Site: www.idwr.idaho.gov

September 1, 2011

C. L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Interim Director

KOOTENAI MEDICAL CENTER
2003 KOOTENAI HEALTH WAY
COEUR D ALENE ID 83814

RE: Permit 95-9395

Dear Permit Holders:

The Department of Water Resources (IDWR) is in the process of reviewing the above-mentioned permit for licensure. As part of our review IDWR evaluates the system capacity, as designed, and any other information regarding the diversion of water from the well. At this time, we don't have enough information to complete a license of permit 95-9395 and hope that you can provide answers to the questions below. Once these questions are answered, IDWR should be able to move forward and license your permit based on your water use.

1. Is there is a pressure switch on the distribution system? If so, what range is the pressure switch set to?
2. What head is the system designed for? I reviewed pump curves for Model 6CHC and Model 33GS—Goulds pumps and can't find a reasonable point on the curve.
3. For the use within the medical center, what capacity or gallons per minute is the overall system designed for?
4. With the understanding that there is one pump for use within the medical center and one pump for irrigation purposes; how do the two pumps work together?

Please respond to this inquiry within 30 days, the information is required and IDWR is hoping to reach a final resolution with permit 95-9395 soon. Please contact me at (208) 287-4944 if you have any questions regarding this matter.

Sincerely,

Cherie Padilla, Sr. Water Resource Agent
Water Allocation Bureau