



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street • P.O. Box 83720 • Boise, Idaho 83720-0098

Phone: (208) 287-4800 • Fax: (208) 287-6700 • Web Site: www.idwr.idaho.gov

August 24, 2011

C. L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Interim Director

CRANE CREEK COUNTRY CLUB
500 W CURLING DR
BOISE ID 83702

RE: Permit 63-12596

Dear Water Right Holder:

The Department of Water Resources (IDWR) is in the process of reviewing the above-mentioned permit for licensure. As part of the review, IDWR confirms that each condition of approval has been met during the development period. In the case of permit 63-12596, it is not apparent how conditions of approval #7, #8, and #9 have been satisfied. Conditions #7, #8 and #9 state:

#7: The right holder shall install measuring devices of a type acceptable to the Department to record the flow rate withdrawn from each point of diversion.


#8: The measuring devices shall be calibrated by a method approved by the Department every three years following the date of this approval.

#9: Each week the water right holder shall read and record instantaneous flow rate and accumulated diversion volume at each of the authorized points of diversion for this right. These records shall be made available to the Department upon request.

At this time IDWR is giving you the opportunity to provide information that clarifies how the three conditions were met. In your response be sure to supply any measurement and calibration data.

Please submit the requested information within 30 days. Pursuant to Section 42-219(6), Idaho Code, if the conditions of approval on a permit are not complied with, we may issue an order voiding the permit.

Please contact me at (208) 287-4944 if you have any questions regarding this matter.

Sincerely,


Cherie Palmer, Sr. Water Resource Agent
Water Allocation Bureau

cc: SPF ENGINEERING