

Weaver, Mathew

From: Roxanne Brown [RBrown@spfwater.com]
Sent: Wednesday, December 28, 2011 4:49 PM
To: Weaver, Mathew
Cc: Terry Scanlan
Subject: RE: WR 63-31949 - Water Bearing Zone Discrepancy

Thought so! Thanks for the quick reply. We'll get this turned around ASAP

Roxanne

From: Weaver, Mathew [mailto:Mathew.Weaver@idwr.idaho.gov]
Sent: Wednesday, December 28, 2011 4:48 PM
To: Roxanne Brown
Subject: RE: WR 63-31949 - Water Bearing Zone Discrepancy

Roxanne,

My mistake. You are correct, I was referencing 63-31243.

Thanks,

Mat

From: Roxanne Brown [mailto:RBrown@spfwater.com]
Sent: Wednesday, December 28, 2011 4:41 PM
To: Weaver, Mathew
Cc: Terry Scanlan; Saxton, Craig
Subject: RE: WR 63-31949 - Water Bearing Zone Discrepancy

Mat,

I assume you are referring to the BUFE for permit 63-31243? I'll review what we did for 63-31949 and get back to you...

Roxanne

From: Weaver, Mathew [mailto:Mathew.Weaver@idwr.idaho.gov]
Sent: Wednesday, December 28, 2011 1:58 PM
To: Roxanne Brown
Cc: Terry Scanlan; Saxton, Craig
Subject: WR 63-31949 - Water Bearing Zone Discrepancy

Roxanne,

As was noted in the beneficial use field report, Belmont Well #1 has a constructed screening interval of 236 to 285 feet, which lies outside the water bearing zone as conditioned on the permit (Condition 11: *'Water bearing zone to be appropriated is 375 to 475 feet'*). On behalf of your client I would ask that you present a letter to the Department requesting a change to the water bearing zone. Similar to the request SPF and the

City of Nampa prepared for water right 63-31949, please include a brief summary of why the change is not a concern for injury to nearby resources and wells.

I appreciate your attention to these matters and anticipate hearing back from you by January 16, 2012. Once these items have been addressed I will finalize the water right license. In the interim, if you have any questions regarding these issues, please drop a line.

Cheers,

Mat Weaver, P.E.
Engineer, Technical 2
Idaho Department of Water Resources
(208) 287-4914