

Weaver, Mathew

From: Weaver, Mathew
Sent: Friday, January 13, 2012 11:36 AM
To: 'Terry Scanlan'
Subject: RE: WR 63-31949 - Water Bearing Zone Discrepancy

Terry,

Thank you. This letter looks good. I will move forward with preparing the order modifying the water bearing zone interval and with the final license.

If you have any questions. Give me a call.

Cheers,

Mat

From: Terry Scanlan [<mailto:TScanlan@spfwater.com>]
Sent: Friday, January 13, 2012 9:29 AM
To: Weaver, Mathew
Cc: Saxton, Craig; Roxanne Brown
Subject: RE: WR 63-31949 - Water Bearing Zone Discrepancy

Hi Mat

Sorry for the slow response. Attached is a letter regarding the water-bearing zone for 63-31243. Let me know if this is sufficient. A hard copy will follow by regular mail.

Have a great weekend.

Terry

From: Weaver, Mathew [<mailto:Mathew.Weaver@idwr.idaho.gov>]
Sent: Wednesday, December 28, 2011 1:58 PM
To: Roxanne Brown
Cc: Terry Scanlan; Saxton, Craig
Subject: WR 63-31949 - Water Bearing Zone Discrepancy

Roxanne,

As was noted in the beneficial use field report, Belmont Well #1 has a constructed screening interval of 236 to 285 feet, which lies outside the water bearing zone as conditioned on the permit (Condition 11: *'Water bearing zone to be appropriated is 375 to 475 feet'*). On behalf of your client I would ask that you present a letter to the Department requesting a change to the water bearing zone. Similar to the request SPF and the City of Nampa prepared for water right 63-31949, please include a brief summary of why the change is not a concern for injury to nearby resources and wells.

I appreciate your attention to these matters and anticipate hearing back from you by January 16, 2012. Once these items have been addressed I will finalize the water right license. In the interim, if you have any questions regarding these issues, please drop a line.

Cheers,

Mat Weaver, P.E.
Engineer, Technical 2
Idaho Department of Water Resources
(208) 287-4914