



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street • P.O. Box 83720 • Boise, Idaho 83720-0098

Phone: (208) 287-4800 • Fax: (208) 287-6700 • Web Site: www.idwr.idaho.gov

December 8, 2011

C. L. "BUTCH" OTTER
Governor

GARY SPACKMAN
Interim Director

US DEPT OF INTERIOR
BUREAU OF RECLAMATION
CO GAIL MCGARRY
1150 N CURTIS RD STE 100
BOISE ID 83706-1234

RE: Modification Request to Condition of Approval for Permit 63-31550 City of Caldwell

Dear Interested Party:

The city of Caldwell filed an Application for Permit No. 63-31550 on September 20, 2002. On October 21, 2002, you, the United States Department of the Interior Bureau of Reclamation (BOR), protested the Application. To solve the protest, the parties agreed to condition the permit and the Idaho Department of Water Resources (IDWR) issued the permit with the following condition:

The well serving as the point of diversion for this right shall be continuously cased and sealed from land surface to the top of the proposed target aquifer at 216 feet below ground level. The full depth surface seal for the well shall consist of solid bentonite chips poured into place as an envelope to a centralized well casing.


The Idaho Department of Water Resources (IDWR) has received a request from the field examiner, Ed Squires of Hyro Logic, Inc., for the city of Caldwell to change the above-mentioned condition to say:

"The well serving as the primary point of diversion for this right shall be continuously cased and sealed from land surface to the top of the completion aquifer at 199 feet below ground level. The seal shall consist of an approved grout pumped into place from the base of the casing, or a solid bentonite chip poured into place, into a uniform annular space surrounding the centralized casing."

For your convenience I have enclosed the Beneficial Use Field Report for your review. Please contact the city of Caldwell directly if you have questions regarding their request. Or you may contact me within 60 days at (208) 287-4944 if you do not agree with the new condition. IDWR may license water right no. 63-31550 as proposed after 60 days.

Page 2
December 8, 2011

Sincerely,

A handwritten signature in cursive script that reads "Cherie Palmer".

Cherie Palmer, Sr. Water Resource Agent
Water Allocation Bureau

C: City of Caldwell
621 Cleveland Blvd
Caldwell, ID 83605

Hydro Logic Inc
Ed Squires
1002 W Franklin St
Boise ID 83702