

Hemenway, Sandy

From: Dr Howard [dental@fiberpipe.net]
Sent: Wednesday, January 11, 2012 3:21 PM
To: Hemenway, Sandy

Sandy

The Water User Association # I and Water User Association # II systems are isolated from each other by a 2" valve on the 2" domestic interconnect line and a 3" valve on the 3" irrigation interconnect line. The only purpose of the interconnect lines is for fire suppression and they will remain closed unless additional water is needed for an emergency. I hope this helps to clarify any questions about the interconnection between the two systems.

Brian