

State of Idaho
Department of Water Resources
Permit to Appropriate Water
NO. 63-33321

Priority: December 21, 2009

Maximum Diversion Rate: 0.06 CFS
Maximum Diversion Volume: 4.2 AF

This is to certify, that ELK CREEK CORP
PO BOX 401
IDAHO CITY ID 83631

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.06 CFS	4.2 AF

LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER NE¼NW¼ Sec. 26, Twp 06N, Rge 05E, B.M. BOISE County

PLACE OF USE: DOMESTIC

Twp Rge Sec	NE	NW	SW	SE	Totals
06N 05E 26	NE NW SW SE	NE NW SW SE	NE NW SW SE	NE NW SW SE	Totals
	X				

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **January 01, 2017**.
2. Subject to all prior water rights.
3. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
4. This right does not grant any right-of-way or easement across the land of another.
5. Domestic use is for internal use for 14 mobile homes and does not include lawn, garden, landscape, or other types of irrigation.
6. Diversion and use of water under this right shall not exceed 0.06 cfs or 4.2 acre-feet per year.
7. After specific notification by the Department, the right holder shall install a suitable measuring device or shall enter into an agreement with the Department to use power records to determine the amount of water diverted and shall annually report the information to the Department.
8. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
9. The well to be constructed as a point of diversion for this right shall be cased and sealed to a depth of at least 60 feet below ground surface.
10. Water bearing zone to be appropriated is from 100 feet to 210 feet below ground surface.

State of Idaho
Department of Water Resources
Permit to Appropriate Water
NO. 63-33321

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Boise, this 8th day of February, 2012.

for Shelley W. Keen
GARY SPACKMAN, Interim Director