

LICENSE REVIEW CHECKLIST

Permit No.

21-7593 Date: 9/8/11

Reviewer: cpdmm

Name/Address:

Change/OK X

Source:

Point of Diversion:

Does change clarify original intended source? If no, void permit

Place of Use:

Change? N

Add? N

F06 (overlap POD)

X59 (subdivision description)

X Centennial Shares Sub + Centennial Mtn Shares Sub

Change N

X60? (subdivision description) MT USdx60
E55? (PPU acre limit) on mtn. subdiv. rights.

The following rights are diverted through point(s) of diversion described above:
F06 The following rights are diverted through point(s) of diversion described above:
X59 Point of diversion is located within <lot 4, Blk. 3, Wilderness Subdivision>
Place of use is located w/ <lots 1-10, Blk. 3 and lots 1-10, Blk. 6; Mountain Ridge Subdivision>
Right Nos. _____ and _____ are limited to the irrigation of a combined total of _____ acres in a single irrigation season.

Diversion Rate:

Permitted Rate: 1.25 cfs

Fee Limit: NA

Measured: 2.77 cfs

Theoretical: 2.77 cfs

Diversion rate from rights with same POD: 1.25

Recommended Total Diversion Rate: 1.25

Total = 1.25

Water Uses:

Y Change? change from domestic to municipal

Irrigation

Stockwater

Domestic

Municipal

Total =

1.25 cfs

99.6 af

SOU:

year-round

Per map submitted 4/18/11, 94 lots have water service connection and 33 lots have water mainline available and be readily connected.

Volume Determination

1.25 cfs x 1.9835 x 365 days = 904.9 af

83 homes series x 1.2 ft/ft 99.6 af

Explanation for rate - DWR standard for in-house use 83 home = 0.445 cfs
Urban irrigation = 41.5 acres x 0.02 = 0.83

0.445 + 0.83 = 1.28 cfs

Additional Conditions

Watermaster Control /

GW Dist? /

Crit. GWMA? /

GWMA? /

Govt Lots? /

Amendment?

Yes - changing water from Domestic to municipal