

MEMORANDUM

Date: November 09, 2007
To: Water Right File 37-8563
From: medl
Re: license review

While reviewing this file for licensing, I found the following worth noting:
This property and the permit have changed ownership since the field exam was done.

Brockway Engineering did the Beneficial Use Field Exam 5/9/2006 and created the POU shape file. The field examiner found 3.6 acres in irrigation at the time of the exam but only 3 acres were applied for in the Permit. I contacted Brockway Engineering by phone on 11/7/2007 and requested that they consult with their client about reducing the irrigated acres. I also asked for a copy of the adjusted shape file. A shape file, and companion projection and database files were emailed to me 11/8/07. I created the POD based on field exam photographs and imagery.

The field examiner recommended 0.10 cfs total diversion rate. However, the system capacity was found to be only 0.9 cfs. I entered 0.9 cfs as the maximum diversion rate for the license.

The POD and POU are in the ESRPA Moratorium area, the Big Wood River GWMA and the Trust Water Moratorium Area. However, the permit was issued before these special administrative areas were inaugurated.

A new well was drilled on the property 8/27/07.