

LICENSE REVIEW CHECKLIST

Permit No.

103-12103

Date: 9/29/11

Reviewer: C Palmer

Name/Address:

Change/OK

Source:

Does change clarify original intended source? If no, void permit

Point of Diversion:

Change?

Add?

F06 (overlap POD)

X59 (subdivision description)

F06

The following rights are diverted through point(s) of diversion described above: .

Place of Use:

Change

X60? (subdivision description)

X60

E55? (PPU acre limit)

E55

Place of use is located w/1 <lots 1-10, Blk. 3 and lots 1-10, Blk. 6, Mountain Ridge Subdivision>. Right Nos. _____ and _____ are limited to the irrigation of a combined total of _____ acres in a single irrigation season.

Overlaps: Right(s):

File Reviewd

Diversion Rate:

Permitted Rate: 0.50 cfs

Fee Limit: PO

Measured: _____ cfs

Theoretical: 0.98 cfs

Diversion rate from rights with same POD: 0.20

Recommended Total Diversion Rate: 0.50

Total = 0.70 cfs

Water Uses:

Change?

Irrigation _____ cfs

Stockwater _____ cfs

Domestic _____ cfs

_____ cfs

_____ cfs

Total = 0.50 cfs

SOU:

Diversion = 3/1-11/15

Volume Determination

0.5 cfs x 1.9835 x 260

vs. 4.5

acres x (FHR)

205 homes x 0.6 af

189 af

123046 -> use this as volume condition since domestic irrigation is limited to 0.6 af/home

No volume assigned - GW is supplemented to SW

Additional Conditions

Watermaster Control

GW Measurement/Measuring devices Water Mgmt. Dist?

Other

GW Dist?

Crit. GWMA?

GWMA?

Govt Lots?

Amendment?

NO

Example license = 103-31859