

Keen, Shelley

From: Charles E. Brockway [charles.e.brockway@brockwayeng.com]
Sent: Thursday, September 08, 2011 4:18 PM
To: Keen, Shelley
Cc: Jim Speck
Subject: License Water Right 37-8388 SDRTR
Attachments: IMG_2017.JPG

Shelly: Thanks for talking with me relative to the draft preliminary order for the license for the geothermal system at SDRTR. As I indicated, the 3 inch diameter pipeline from the geothermal water collector to the home and facilities includes a valve and magnetic flow meter as shown in the attached photo. The installed valve is a PVC non-lockable ball valve so it does not meet the criteria for a controllable, lockable headgate.

I am asking the contractor, David Rosser, to install a 3 inch resilient seated butterfly valve with manual operated level handle with pad locking capability to prevent unauthorized operation.(VALTORC Series 100 or equivalent) This will allow locked, variably adjusted flow and access to the valve and flow meter in the same location. I believe this satisfies the statutory requirement for the diversion.

I will request Mr. Rosser to get the new valve installed as soon as possible and, I understand, you will soon issue or have issued a draft license.

Thanks for your help

Charles E. Brockway P.E. PhD.
Brockway Engineering
2016 Washington Street North
Twin Falls, ID 83301
208 736 8543

