

LICENSE REVIEW CHECKLIST

Permit No. 73-11961 Date: 10/4/2011 Reviewer: Craig L. Saxton

Name/Address: Ok

Source: Ok

Point of Diversion: Yes Change?
yes Add? **Need to add 2 POD's**
No F06 (overlap POD)
No X59 (subdivision description)

Place of Use: No Change
No X60? (subdivision description)
NO E55? (PPU acre Limit)
No Overlaps: Right(s): _____

Diversion Rate:
 Permitted Rate: 14 cfs
 Fee Limit: _____ cfs
 Measured: 13.53 cfs
 Theoretical: _____ cfs
 Recommended Total Diversion Rate: 13.53 cfs
 Diversion rate from rights with same POD: _____
 Total = 13.53

Water Uses: _____ Change? Changed Dom & irrigation to just Domestic use
 Irrigation _____ cfs _____ af
 Domestic _____ cfs _____ af
 Municipal _____ cfs _____ af
 Storage _____ cfs _____ af
 Fish Propagation 13.53 cfs 6669 af
 Total = _____ cfs _____ af
 SOU: _____
 Evap Loss: _____ Seep Loss 0

Volume Determination
 _____ cfs x 1.9835 x _____ days = 0 af
 vs.
 _____ acres x _____ (FHR) 0 af
 Dom uses @ 0.6 AF per use = 0 Total Max Div Vol = 6669

Remarks: See memo for diversion vol calculations
POD amendment: Even if the intent were to list 3 POD's, there is a change in the QQQ designation.

Additional Conditions
 _____ Watermaster Control
 _____ GW Measurement/Measuring devices
 _____ Other
 GW Dist? _____
 Water Msmt. Dist? _____
 Crit. GWMA? _____
 GWMA? _____
 Govt Lots? _____

yes/no
 Advance Priority? _____ If yes, explain why below: _____
 Adjust Memo _____