

MEMORANDUM

Date: August 24, 2011
To: Application for Permit 37-22661 - City of Carey
From: Jeanie Robertson
Re: Evaluation of Sufficiency of Information Submitted

Application for Permit proposes to divert an additional 1.45 cfs from an existing well for Municipal use within the service area of the City of Carey. The existing well is located near the north end of Carey approximately ¼ mile east of HWY 93 north of the high school. Permit 37-21243 is also diverted from this well. It was permitted for 0.6 cfs but Cindy measured 2.05 cfs, so this permit aims to capture the additional rate of flow she measured. There are several permits under the City of Carey currently waiting for exams and licensing. Once they are all licensed, they plan to file a transfer to tie all the wells together...