



RECEIVED
MAY 09 2011
DEPARTMENT OF WATER RESOURCES

DEPARTMENT OF WATER RESOURCES
MAY 09 2011
RECEIVED

To: **Evan Love**
elove@readytek.net
801-940-0045 (f) 801-444-3889
Re: Canyon Estates
Attention: Nick Van Dyke, Idaho Dept. of Water

May 3, 2011

To whom it may concern:

Installed 15 HP Goulds #95L15
Sub Pump on 8/13/2009
Pump is set at 300 feet
Pumped at 110 GPM

On Saturday September 4th, 2010 Glenn's Electric was called to Canyon Estates because they were out of water on a busy holiday weekend. We found the #1 Well pump was grounded and would not pump. We turned on Well #2 to get water and found that it would run dry within a few minutes of operation, we performed more checks and confirmed that Well #2 was running out of water shortly after start-up.

Thank you,

Kent Glenn

Glenn's Electric
501 N Main
Logan, UT 84321
435-752-4178