


Idaho Department of Water Resources



Quick Search:

[For assistance, email WMIS Info](#)

Search Method:

Contact

First Name

Last Name

Organization

udderly gold%

Search

You are logged in as jreeder

[Point Of Diversion](#)
[PCC](#)
[Flow Meter](#)
[Time Clock](#)
[Alternate](#)
[Contacts](#)
[Data Summary](#)
[Other](#)
[Logout](#)

Flow Meter Calibrations

You are viewing 400184; A0011860

[Click here to insert a new record.](#)

Edit	Delete	Calibration Date/Time:*	10/04/2007	Factor:	0.97
		Installed Meter Data:		Standard Meter Data:	
		Installed Meter Flow:	36.30	Standard Meter Flow:	35.30
		Rate Unit:*	GPM	Rate Unit:	GPM
		Rate Multiplier:*	1.0000	Pipe Material:	STEEL
		Volume Multiplier:*	100.0000	Outside Diameter (Inches):	2.38
		Volume Unit:*	GAL	Wall Thickness (Inches):	0.16
		Location:	FAIR	Downstream Distance (feet):	1.00
		Comments:		Upstream Distance (feet):	1.00
		First line flow meter goes to house Dairy is 2nd Line water coming in. Cycling. replaces capped well A0011880.		Calibration Confidence:	GOOD
		Installed Meter Information:			
		Manufacturer:	MASTER	Installation Date:	
		Model Number:		Serial Number:	
		Meter Type:		Other Well:	
Edit	Delete	Calibration Date/Time:*	03/18/2004	Factor:	0.90
		Installed Meter Data:		Standard Meter Data:	
		Installed Meter Flow:	35.07	Standard Meter Flow:	31.55
		Rate Unit:*	GPM	Rate Unit:	GPM
		Rate Multiplier:*	1.0000	Pipe Material:	STEEL
		Volume Multiplier:*	100.0000	Outside Diameter (Inches):	2.40
		Volume Unit:*	GAL	Wall Thickness (Inches):	0.14
		Location:	FAIR	Downstream Distance (feet):	0.00
		Comments:		Upstream Distance (feet):	0.00
		Will recheck in May of 04' to see if meter is holding at 11% high?		Calibration Confidence:	POOR
		Installed Meter Information:			
		Manufacturer:	MASTER	Installation Date:	
		Model Number:		Serial Number:	
		Meter Type:	IMPELLER	Other Well:	
Edit	Delete	Calibration Date/Time:*	05/22/2003	Factor:	0.81
		Installed Meter Data:		Standard Meter Data:	
		Installed Meter Flow:	31.20	Standard Meter Flow:	25.40
		Rate Unit:*	GPM	Rate Unit:	GPM

	Rate Multiplier:*	1.0000	Pipe Material:	STAINLESS
	Volume Multiplier:*	100.0000	Outside Diameter (Inches):	2.40
	Volume Unit:*	GAL	Wall Thickness (Inches):	0.15
	Location:	FAIR	Downstream Distance (feet):	1.50
	Comments:	A second test returned similar results. Meter must be replaced.	Upstream Distance (feet):	1.50
			Calibration Confidence:	POOR
	Installed Meter Information:			
	Manufacturer:	MASTER	Installation Date:	
	Model Number:		Serial Number:	
	Meter Type:	PROPELLER	Other Well:	