




City of Wilder
219 Third Street, P.O. Box 687
Wilder, Idaho 83676

(208) 482-6204 Fax: (208) 482-7890
www.cityofwilder.org

RECEIVED

MAR 31 2011

DEPARTMENT OF WATER RESOURCES

23 March 2011

RECEIVED

MAR 30 2011

WATER RESOURCES
WESTERN REGION

Department of Water Resources
2735 Airport Way
Boise, Idaho 83705-5082
Attn: Jean Hersley
334-2190

RE: City Of Wilder Water Right Number 63-33332 Proof Of Beneficial Use

Dear Jean:

Please be informed that the irrigation well referenced in this proof of beneficial use was flow tested on 22 March 2011 with the following results:

At approximately 15:00 HRS local time, a portable Neptune 2" direct read water meter was attached to an auxiliary discharge port on the well. The well pump was energized and allowed to run for approximately 15 minutes to allow the well to stabilize. Two time trials were then conducted to ascertain the well's potential volumetric flow rate. Each time trial showed a production rate of approximately 220 gallons per minute.


Converting the volumetric flow rate from gallons per minute to cubic feet per second to match the application shows approximately 0.4902 cubic feet per second.

It is our understanding that this flow rate test coupled with the attached run time logs and power bills is sufficient information to support the proof of beneficial use requirement.

Please contact me at 467-5252 if you have any questions or you detect any anomalies.

Respectfully,

Paul A. Stevens, P.E.
Wilder City Engineer



23 MARCH 2011

CC: Mayor Bechtel, City Clerk, Public Works Director