

January 24, 2011

Kevin and Katherine Banner
PO Box 523
Albion, ID 83311

RE: Measurement Plan follow-up

Dear water user,

I have received your measurement plan form(s) as required by the June 25, 2009 measurement order. I have reviewed your plan(s) and any prior measurements or information we have regarding this diversion system. Your measurement plan is for a **NEW** meter installation that meets IDWR minimum acceptable standards for measurement. This letter is to inform you that IDWR can not approve your plan due to the lack of information related to the brand and style of magnetic flow meter you plan to install on the well.

Under the measurement order issued on June 25, 2009, water users are to have meters installed that meet the standards outlined in the attached minimum acceptable standards prior to irrigation in 2011. Please submit the additional information and any installation plans you have for your wells by February 15, 2011.

There are magnetic flow meter dealers set up in your area who are able to help you with the decision of the meter you will be installing on your system. If you have any additional questions related to the order please contact me at 208-287-4842. Thank you for your attention to this matter.

Regards,

Corbin Knowles
IDWR- Water Distribution Section
Boise

Cc Brian Higgs, Watermaster WD 140