



STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

RECEIVED

JUN 12 2004

WATER RESOURCES
WESTERN REGION

1445 North Orchard • Boise, Idaho 83706-2239 • (208) 373-0550

Dirk Kempthorne, Governor
C. Stephen Allred, Director

June 14, 2004

Sue Kreger
Idaho Department of Water Resources
2735 Airport Way
Boise, ID 83705-5082

RE: Water Right No. 63-31877 in the name of Graham and Jordan Investors LLC

Dear Ms. Kreger:


We have the following general comments regarding this project:

Potable Water Supply

This project proposes modifications to an existing public drinking water system. Per *Idaho Code* § 39-118 and the associated *Idaho Rules for Public Drinking Water Systems*, all components of public water system construction, including wells, must be designed by an Idaho registered professional engineer (engineer) and approved by the Idaho Department of Environmental Quality (IDEQ) prior to construction.

If you have any questions, please contact me at (208) 373-0162, or via e-mail at srae@deq.state.id.us.

Sincerely,



Stephen H. Rae, P.E.
Staff Engineer

SHR:vee G:\Engineering\Srae\Reviews\Planning and Zoning Comments\IDWR-63-31877-Graham and Jordan_06-14-04.doc

cc: Charles W. Ariss, P.E., Regional Manager-Engineering, Boise Regional Office
File 24, Manager's File, Reading File

NOT RECORDED

JUN 15 2004