

Permit No. 95-9555

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
Staff Analysis Field Report for Exempted Wells

1. ☒ Copy of Permit
2. ☒ Copy of proof of beneficial use Letter
3. ☐ Copies of amendments, orders with conditions
4. ☒ Permit is for one owner
5. ☒ Confirm one owner of the place of use
 - ☒ Tax lot Research
 - ☐ Telephone call
 - ☐ Office visit
6. ☒ Aerial photo of parcel for the water right file (copy of aerial required)
7. ☒ Well driller's report
8. ☒ Domestic use only
9. ☒ 0.04 cfs or less on water permit
10. ☐ Check if alternative source of water is available for domestic use
11. ☐ Other information:

AUTHENTICATION

Examiner Name Eric [Signature] Date 1-28-2011

Reviewer [Signature] Date 2/23/2011

SCANNED
FEB 24 2011

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 95-09555

Priority: November 14, 2008

Maximum Diversion Rate: 0.04 CFS

This is to certify, that

JAMES WILSON And/Or
GERALDINE WILSON
7782 SAUSSER DR
COEUR D ALENE ID 83814
(208)666-9615

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
DOMESTIC	01/01 to 12/31	0.04 CFS

LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER, NW $\frac{1}{4}$ SE $\frac{1}{4}$ NW $\frac{1}{4}$, Sec. 5, Twp 49N, Rge 04W, B.M., KOOTENAI County


PLACE OF USE: DOMESTIC

Twp Rge Sec	NE				NW				SW				SE				Totals
	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
49N 04W 5								X									

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **February 01, 2010**.
2. Subject to all prior water rights.
3. Domestic use is for 1 home.
4. The irrigation occurring under this domestic use shall not exceed 1/2 acre.
5. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
6. This right does not grant any right-of-way or easement across the land of another.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Coeur d'Alene, this 20th day of January, 2009.


DAVID R. TUTHILL, JR., Director

State of Idaho
Department of Water Resources
Water Right License
95-9555
Water Service Area Boundary for James Wilson



Legend

-  Point of Diversion
-  Place Of Use Boundary
-  Townships
-  PLS Sections
-  Quarter Quarters
-  Taxlots

0 0.025 0.05 0.1 Miles



STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES

RECEIVED

JUL 19 1993

USE TYPEWRITER OR
BALLPOINT PEN

WELL DRILLER'S REPORT

State law requires that this report be filed with the Director, Department of Water Resources
within 30 days after the completion or abandonment of the well.

1. WELL OWNER Name <u>MR. DAVE DABOLL</u> Address <u>505 FRONT AVE COEUR D'ALENE ID 83814</u> Drilling Permit No. <u>95-93-N-87-000</u> Water Right Permit No. _____		7. WATER LEVEL Static water level <u>45</u> feet below land surface. Flowing? ☐ Yes ☐ No G.R.M. flow _____ Artesian closed-in pressure _____ p.s.i. Controlled by: ☐ Valve ☐ Cap ☐ Plug Temperature <u>cold</u> of _____ Quality <u>Good</u> Describe extension or temperature zones below: _____																																																																							
2. NATURE OF WORK ☒ New well ☐ Deepened ☐ Replacement ☐ Well diameter increase ☐ Modification ☐ Abandoned (describe abandonment or modification procedures such as liners, screen, materials, plug depths, etc. in lithologic log, section 8.)		8. WELL TEST DATA ☐ Pump ☐ Bailor ☒ Air ☐ Other _____ <table border="1"><thead><tr><th>Discharge G.R.M.</th><th>Pumping Level</th><th>Hours Pumped</th></tr></thead><tbody><tr><td>60 GPM</td><td></td><td></td></tr></tbody></table>		Discharge G.R.M.	Pumping Level	Hours Pumped	60 GPM																																																																		
Discharge G.R.M.	Pumping Level	Hours Pumped																																																																							
60 GPM																																																																									
3. PROPOSED USE ☒ Domestic ☐ Irrigation ☐ Monitor ☐ Industrial ☐ Stock ☐ Waste Disposal or Injection ☐ Other _____ (specify type)		9. LITHOLOGIC LOG <u>89394</u> <table border="1"><thead><tr><th rowspan="2">Bore Diam.</th><th colspan="2">Depth</th><th rowspan="2">Material</th><th colspan="2">Water</th></tr><tr><th>From</th><th>To</th><th>Yes</th><th>No</th></tr></thead><tbody><tr><td>8</td><td>0</td><td>5</td><td>SAND & GRAVEL FILL</td><td></td><td>X</td></tr><tr><td>5</td><td>5</td><td>19</td><td>DECOMPOSED GRANITE BROWN</td><td></td><td>X</td></tr><tr><td>6</td><td>19</td><td>24</td><td>DECOMPOSED GRANITE BROWN</td><td></td><td>X</td></tr><tr><td>6</td><td>24</td><td>30</td><td>GRANITE BLACK & GREEN SOFT</td><td></td><td>X</td></tr><tr><td>6</td><td>30</td><td>70</td><td>GRANITE TAN MEDIUM</td><td></td><td>X</td></tr><tr><td>6</td><td>70</td><td>111</td><td>GRANITE SALT & PEPPER W/GREEN SCALES</td><td></td><td>X</td></tr><tr><td>6</td><td>111</td><td>157</td><td>GRANITE PEPPER W/GREEN MED W/WATER APPROXIMATELY 5% MED</td><td>X</td><td></td></tr><tr><td>6</td><td>157</td><td>170</td><td>GRANITE GREEN & WHITE SOFT</td><td>X</td><td></td></tr><tr><td>6</td><td>170</td><td>176</td><td>GRANITE BLACK FRACTURED W/ WATER 60GPM</td><td>X</td><td></td></tr><tr><td>6</td><td>176</td><td>180</td><td>GRANITE BLACK W/GREEN HARD</td><td></td><td>X</td></tr></tbody></table> NOTE: 153' OF 160psi PVC		Bore Diam.	Depth		Material	Water		From	To	Yes	No	8	0	5	SAND & GRAVEL FILL		X	5	5	19	DECOMPOSED GRANITE BROWN		X	6	19	24	DECOMPOSED GRANITE BROWN		X	6	24	30	GRANITE BLACK & GREEN SOFT		X	6	30	70	GRANITE TAN MEDIUM		X	6	70	111	GRANITE SALT & PEPPER W/GREEN SCALES		X	6	111	157	GRANITE PEPPER W/GREEN MED W/WATER APPROXIMATELY 5% MED	X		6	157	170	GRANITE GREEN & WHITE SOFT	X		6	170	176	GRANITE BLACK FRACTURED W/ WATER 60GPM	X		6	176	180	GRANITE BLACK W/GREEN HARD		X
Bore Diam.	Depth		Material		Water																																																																				
	From	To		Yes	No																																																																				
8	0	5	SAND & GRAVEL FILL		X																																																																				
5	5	19	DECOMPOSED GRANITE BROWN		X																																																																				
6	19	24	DECOMPOSED GRANITE BROWN		X																																																																				
6	24	30	GRANITE BLACK & GREEN SOFT		X																																																																				
6	30	70	GRANITE TAN MEDIUM		X																																																																				
6	70	111	GRANITE SALT & PEPPER W/GREEN SCALES		X																																																																				
6	111	157	GRANITE PEPPER W/GREEN MED W/WATER APPROXIMATELY 5% MED	X																																																																					
6	157	170	GRANITE GREEN & WHITE SOFT	X																																																																					
6	170	176	GRANITE BLACK FRACTURED W/ WATER 60GPM	X																																																																					
6	176	180	GRANITE BLACK W/GREEN HARD		X																																																																				
4. METHOD DRILLED ☒ Rotary ☒ Air ☐ Auger ☐ Reverse rotary ☐ Cable ☐ Mud ☐ Other _____ (backhoe, hydraulic, etc.)																																																																									
5. WELL CONSTRUCTION Casing schedule: ☒ Steel ☐ Concrete ☐ Other _____ Thickness <u>1/2</u> inches Diameter <u>6</u> inches Tip <u>20</u> feet pvc <u>160psi</u> inches <u>4</u> inches <u>7</u> feet <u>160</u> feet inches inches feet feet Was casing drive shoe used? ☒ Yes ☐ No Was a packer or seal used? ☐ Yes ☒ No Perforated? ☐ PVC ☒ Yes ☐ No Skill Saw How perforated? ☐ Factory ☐ Knife ☐ Torch ☐ Gun Size of perforation? <u>1/4</u> inches by <u>4</u> inches Number From To 20 perforations 140 feet 180 feet perforations feet feet perforations feet feet Well screen installed? ☐ Yes ☒ No Manufacturer _____ Type _____ Top Packer or Headpipe _____ Bottom of Tailpipe _____ Diameter _____ Slot size _____ Set from _____ feet to _____ feet Diameter _____ Slot size _____ Set from _____ feet to _____ feet Gravel packed? ☐ Yes ☐ No ☐ Size of gravel _____ Placed from _____ feet to _____ feet Surface seal depth <u>19</u> Material used in seal: ☐ Cement grout ☒ Bentonite ☐ Puddling clay ☐ _____ Sealing procedure used: ☐ Slurry pit ☐ Temp. surface casing ☒ Overbore to seal depth Method of joining casing: ☐ Threaded ☒ Welded ☐ Solvent Weld ☐ Cemented between strings Describe access port _____																																																																									
6. LOCATION OF WELL Sketch map location must agree with written location. Subdivision Name _____ Lot No. _____ Block No. _____ County <u>Kootenai</u> Address of Well Site <u>Souther Drive</u> (give at least name of road) T. <u>49</u> N ☐ or S ☐ SE ☐ NW ☐ Sec. <u>5</u> R. <u>4</u> E ☐ or W ☐		10. Work started <u>05/27/93</u> finished <u>05/27/93</u>																																																																							
11. DRILLER'S CERTIFICATION I/We certify that all minimum well construction standards were complied with at the time the rig was removed. Firm Name <u>H2O WELL SERVICE</u> Firm No. <u>6448</u> Address <u>302 W HAYDEN AVE</u> Date <u>05/27/93</u> Signed by Drilling Supervisor <u>[Signature]</u> and (Operator) <u>[Signature]</u> (If different than the Drilling Supervisor)																																																																									

USE ADDITIONAL SHEETS IF NECESSARY — FORWARD THE WHITE COPY TO THE DEPARTMENT

Well ID 273,738
Permit ID 153514

RECEIVED
JAN 23 2009
IDWR/North

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
STATEMENT OF COMPLETION
FOR SUBMITTING PROOF OF BENEFICIAL USE

FOR OFFICE USE ONLY
Amt. of Fee \$: 50.00
Receipt No. N019830
Receipt By: 0
Date Received: 1/23/09

The Idaho Department of Water Resources considers this form a statement by the permit holder(s) that development of a water right has been completed and that water has been applied to beneficial use to the extent described below. This form must be accompanied by an examination fee, when necessary, or by a completed Beneficial Use Field Report prepared by a certified water right examiner. Please refer to the instructions and fee schedule for this form. If ownership of the permit has changed, please contact any Department office or visit the Department's website at: www.idwr.idaho.gov for an Assignment of Permit form. If you wish to relinquish your permit because you have not established the authorized use of the water and are not applying for an extension, please notify the Department in writing.

1. Permit No. 95-09555 Telephone No. 208-666-9615
2. Name of Permit Holder(s): James Wilson and/or Geraldine Wilson
3. Mailing Address: 7782 Sausser Dr City Coeur d'Alene
State ID Zip 83814 Email: jgwilson1@verizon.net
4. Source of Water: Ground water If GROUND WATER (well), Date Drilled: mo. 5 / yr. 93
Well Driller: H2O Well Service Drilling Permit Number: 753514
5. Extent of use(s) completed (as authorized by the water right permit):
Domestic (No. of households): 1 Stockwater (No. and type of stock): _____
Irrigation (No. of acres): _____ Other: _____
6. Total rate of diversion or storage volume for which proof is submitted: 0.04 cfs OR _____ acre-feet.
7. Compliance with a Measuring Device requirement and/or other Conditions of Permit: (Refer to the approval conditions on your permit and respond accordingly.)
Measuring Device: Is a measuring device required? Yes ☐ or No ☒
If yes, has the measuring device been installed? Yes ☐ or No ☐
Conditions of Permit: Does your permit require you to submit additional information in connection with your proof of beneficial use? (If yes, please list the conditions below and provide documents if necessary.)
N/A Completed? Yes ☐ or No ☐
Completed? Yes ☐ or No ☐
8. Fee Enclosed: \$ 50.00 (See Fee Schedule on back of the instructions for filing proof of beneficial use. Proofs filed without an appropriate fee, will be considered incomplete.)

9. Person to contact to accompany the Department representative during field examination of the water system.

Name: Jim Wilson Telephone Number: 208-666-9615
Mailing Address: 7782 Sausser Dr City Coeur d'Alene
State ID Zip 83814 Email: jgwilson1@verizon.net

10. The information given on this form is my true statement of the extent to which the above numbered permit has been developed and water has been diverted and applied to a beneficial use. I understand that any undeveloped portion of the permit is relinquished to the State of Idaho.

Signature of permit holder: James Wilson Date: 1-23-09
(include your title, if on behalf of company or organization)

SCANNED
JAN 26 2009



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street • P.O. Box 83720 • Boise, Idaho 83720-0098

Phone: (208) 287-4800 • Fax: (208) 287-6700 • Web Site: www.idwr.idaho.gov

March 16, 2009

C. L. "BUTCH" OTTER
Governor

DAVID R. TUTHILL, JR.
Director

JAMES AND/OR GERALDINE WILSON
7782 SAUSSER DR
COEUR D ALENE ID 83814

PROOF ACKNOWLEDGMENT LETTER

Re: Permit 95-9555

Dear Permit Holders:

The department acknowledges receipt of the proof of beneficial use ("proof") form submitted for the above-referenced permit. The next step in the process of developing a water right is for the department to conduct the field examination to determine and confirm the use of the water, and that it meets the permitted beneficial use.

It has been noted you have over paid your permit fee and a \$50.00 refund will be sent to you. There are no fees based on groundwater .04cfs or less.

Be advised that Section 42-248, Idaho Code, requires you or the owner of this water right to maintain current ownership and address records on file with the department. Forms to file a change of ownership of a water right and/or a change in the address of the water right owner are available from any department office, or at the department's website at: www.idwr.idaho.gov

If you have questions about the field examination, please contact the Northern Regional Office of the department in Coeur d'Alene at (208) 762-2800.

Sincerely,

Christine Roberts

Christine Roberts
Technical Records Specialist
IDWR State Office

Encl: