

Permit No. 95-10025

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
Staff Analysis Field Report for Exempted Wells

1. ☒ Copy of Permit
2. ☒ Copy of proof of beneficial use
3. ☐ Copies of amendments, orders with conditions
4. ☒ Permit is for one owner
5. ☒ Confirm one owner of the place of use
 - ☒ Tax lot Research
 - ☐ Telephone call
 - ☐ Office visit
6. ☒ Aerial photo of parcel for the water right file (copy of aerial required)
7. ☒ Well driller's report
8. ☒ Domestic use only
9. ☒ 0.04 cfs or less on water permit
10. ☐ Check if alternative source of water is available for domestic use
11. ☒ Other information: Permit is for 0.02 cfs

This Permit was renumbered from 96-9294 to 95-10025

AUTHENTICATION

Examiner Name *Jim Ringer* Date 4-30-2010

Reviewer *Shirley Hale* Date 11/2/11




Idaho Department of Water Resources

Water Right
95-10025
(DOMESTIC)

Legend

- Point of Diversion
- Place of Use
- State Outline
- Townships
- PLS Sections
- Quarter Quarters
- Taxlots



Kootenai County
IDWR Basin 95



Prepared by Eric Davis
On April 20, 2010
2004 Aerial Photography

0 0.05 0.1 0.2 Miles

RECEIVED

Form No. 247
8708

AUG 04 2009

JUL 20 2009

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
STATEMENT OF COMPLETION

FOR OFFICE USE ONLY
Amt. of Fee \$: 0
Receipt No.:
Receipt By:
Date Received:

DEPARTMENT OF WATER RESOURCES DEPARTMENT OF WATER RESOURCES
FOR SUBMITTING PROOF OF BENEFICIAL USE

The Idaho Department of Water Resources considers this form a statement by the permit holder(s) that development of a water right has been completed and that water has been applied to beneficial use to the extent described below. This form must be accompanied by an examination fee, when necessary, or by a completed Beneficial Use Field Report prepared by a certified water right examiner. Please refer to the instructions and fee schedule for this form. If ownership of the permit has changed, please contact any Department office or visit the Department's website at: www.idwr.idaho.gov for an Assignment of Permit form. If you wish to relinquish your permit because you have not established the authorized use of the water and are not applying for an extension, please notify the Department in writing.

1. Permit No. PHILIP LASSWELL Telephone No. 683-3406

2. Name of Permit Holder(s):

3. Mailing Address: Box 1014 City ATHOL

State ID Zip 83801 Email:

4. Source of Water: GROUNDWATER (well), Date Drilled: mo. / yr.

Well Driller: UNITED DRILLING Drilling Permit Number: D0028268

5. Extent of use(s) completed (as authorized by the water right permit):

Domestic (No. of households): 1 Stockwater (No. and type of stock):

Irrigation (No. of acres): Other:

6. Total rate of diversion or storage volume for which proof is submitted: 0.02 cfs OR acre-feet.

7. Compliance with a Measuring Device requirement and/or other Conditions of Permit: (Refer to the approval conditions on your permit and respond accordingly.)

Measuring Device: Is a measuring device required?
If yes, has the measuring device been installed?

Yes ☐	or No ☒
Yes ☐	or No ☐

Conditions of Permit: Does your permit require you to submit additional information in connection with your proof of beneficial use? (If yes, please list the conditions below and provide documents if necessary.)

Completed?	Yes ☐	or No ☐
Completed?	Yes ☐	or No ☐

8. Fee Enclosed: \$ 0 (See Fee Schedule on back of the instructions for filing proof of beneficial use. Proofs filed without an appropriate fee, will be considered incomplete.)

9. Person to contact to accompany the Department representative during field examination of the water system.

Name: Philip C. Lasswell Telephone Number: (208) 277-7299

Mailing Address: P.O. Box 1014 City Athol

State ID Zip 83801 Email: alpacaphil@aol.com

10. The information given on this form is my true statement of the extent to which the above numbered permit has been developed and water has been diverted and applied to a beneficial use. I understand that any undeveloped portion of the permit is relinquished to the State of Idaho.

Signature of permit holder: Philip C. Lasswell Date: 7-29-2009
(include your title, if on behalf of company or organization)

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 96-09294

Priority: July 27, 2006

Maximum Diversion Rate: 0.02 CFS

This is to certify, that PHILIP C LASSWELL And/Or
ROBERT A SHAILER
PO BOX 34
MARSHALL WA 99020

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
DOMESTIC	01/01 to 12/31	0.02 CFS

LOCATION OF POINT OF DIVERSION:

GROUND WATER SE¼ NE¼ Sec. 7, Twp 53N, Rge 03W, B.M. KOOTENAI County

PLACE OF USE: DOMESTIC

Twp Rge Sec	NE				NW				SW				SE				Totals
	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
53N 03W 7				X													

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **January 01, 2010**.
2. Subject to all prior water rights.
3. Domestic use is for 1 home.
4. The domestic use authorized under this right shall not exceed 13,000 gallons per day per home.
5. The irrigation occurring under this domestic use shall not exceed 1/2 acre.
6. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
7. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.
8. This right does not grant any right-of-way or easement across the land of another.
9. When notified by the Department, the right holder shall install and maintain a measuring device of a type acceptable to the Department as part of the diverting works.

State of Idaho
Department of Water Resources
Permit to Appropriate Water
NO. 96-09294

10. This right authorizes the diversion of ground water within the Rathdrum Prairie Ground Water Management Area (RPGWMA). Use of water under this right shall be subject to the provisions of the management plan approved by the director for the RPGWMA.
11. When notified by the Department, the right holder shall record the quantity of water diverted and annually report diversions of water and/or other pertinent hydrologic and system information as required by Section 42-701, Idaho Code, and/or the management plan for the Rathdrum Prairie Ground Water Management Area.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Boise, this 25th day of January, 2007.


Shelley W. Ken
FOR DAVID R. TUTHILL, JR., Interim Director

96-9294



0.08 0 0.08 0.16 Miles

-  Kootenai taxlots
-  GCDB53N03W GCDB
-  Pou.shp
-  Pod.shp
-  Administrative BasinsAdminbas.shp



Form 238-7
11/97

IDAHO DEPARTMENT OF WATER RESOURCES
WELL DRILLER'S REPORT

Office Use Only
Inspected by _____
Twp _____ Rge _____ Sec _____
1/4 1/4 1/4
Lat: : : Long: : :

Receipt NO 15533
\$75.00 fee

1. WELL TAG NO. D0028268 RECEIVED

DRILLING PERMIT NO. 801039 JUN 8 3 2003

Other IDWR No. _____

2. OWNER: IDWR/North

Name Dale Adickes

Address 1726 W Hillside Road

City Athol State ID Zip 83801

3. LOCATION OF WELL by legal description:

N Twp 53N North ☒ or South ☐
Rge 03W East ☐ or West ☒
Sec 07 SE 1/4 (NE) 1/4 NE 1/4
10 Ac 40 Ac 160 Ac
Gov't Lot _____ County Kootenai
Lat _____ Long _____
Address of Well Site: (see next line)
City _____
Clayton _____
Lot _____ Bk _____ Sub. Name (see next line) _____

Clayton

Lot _____ Bk _____ Sub. Name (see next line) _____

4. USE:

☒ Domestic ☐ Municipal ☐ Monitor ☐ Irrigation
☐ Thermal ☐ Injection ☐ Other

5. TYPE OF WORK check all that apply (Replacement etc.)

☒ New Well ☐ Modify ☐ Abandonment ☐ Other

6. DRILL METHOD

☒ Air Rotary ☐ Cable ☐ Mud Rotary ☐ Other

7. SEALING PROCEDURES

SEAL/FILTER PACK			Amount	Method
Material	From	To	Sacks/Lbs	
Bentonite Grn.	0	18	5 Sacks	Pour In

Drive Shoe Used? ☒ Y ☐ N Shoe Depth(s) _____ Ring BH @523'

Drive Shoe Seal Tested? ☐ Y ☒ N How? _____

8. CASING/LINER

Diam	From	To	Gauge	Material	Casing	Liner	Weld	Thread
8	+2	523	0.250	Steel	☒	☐	☒	☐
					☐	☐	☐	☐
					☐	☐	☐	☐

Length Headpipe _____ Length Tailpipe _____

9. PERFORATIONS/SCREENS

☒ Perforations? Method Air Perforator

☐ Screens? Screen Type _____

From	To	Slot	Nmbr	Diam	Material	Casing	Liner
490	510	1x1/4	200	1/2"	Steel	☒	☐
						☐	☐
						☐	☐

10. STATIC WATER LEVEL or ARTESIAN PRESSURE

475 ft. below ground. Artesian pressure _____ lb.
Depth flow encountered 475 ft. Describe access port or
control devices: Steel Cap Welded

11. WELL TESTS

☐ Pump ☐ Sailer ☒ Air ☐ Flowing Artesian

Yield gal./min.	Drawdown	Pump Level	Time
15+	100%	520	3 Hours

Water Temp. _____ Cold _____ Bottom hole tem _____ Cold _____

Water Quality test or comments: (below) Depth first Water Encountered 470

Clear, Cold, No Smell

12. LITHOLOGIC LOG (Describe repairs or abandonment)

Bore Diam	From	To	Remarks: Lithology, Water Quality and Temperature	Water Y N
10	0	1	Topsoil	☐ ☒
8	1	18	Sand & Gravel - 3/4 minus	☐ ☒
8	18	187	Sand & Gravel - 3/4 minus	☐ ☒
8	187	290	Sand & Gravel - 1/2 minus	☐ ☒
8	290	295	Boulder	☐ ☒
8	295	440	Sand & Gravel - 3/4 minus	☐ ☒
8	440	470	Sand & Gravel with some Clay - 3/4 minus	☐ ☒
8	470	523	Sand & Gravel - 3/4 minus	☒ ☐

Completed Depth 523 (Measurable)
Date: Started 5/14/03 Completed 5/19/03

13. DRILLERS CERTIFICATION

I/We certify that all minimum well construction standards were complied with at the time the rig was removed.

Firm Name: United Drilling Inc.

Firm No 414

Firm Official and

Jason C. Beckham

Date 5/21/03

Supervisor or Operator Jason C. Beckham

Date 5/21/03

53 N 3 W 7