

Edl, Michele

Subject: FW: 72-7392 (Stricklan)

From: Miller, Nick
Sent: Friday, November 05, 2010 10:21 AM
To: Edl, Michele
Subject: RE: 72-7392 (Stricklan)

Michelle,

I looked at this one and I see that it is recommended to be licensed at a diversion rate of 0.16 cfs, rather than 1.0 cfs as in the permit. You should talk to Shelley about whether the lack of a measuring device constitutes a failure to develop the permit appropriately, or if we can issue the license and waive the measurement device requirement, and condition the right using the current standards.

I, as Watermaster, have no problem waiving the measuring device requirement on this appropriation as long as it is licensed at the lower rate as recommended.

Nick Miller, P.E.
Staff Engineer
Water Distribution
Idaho Department of Water Resources
322 E. Front St. Boise, ID 83720-0098
208-287-4956 (Office)
208-287-6700 (Fax)
