

State of Idaho
Department of Water Resources
Permit to Appropriate Water
NO. 15-07332

Priority: September 28, 2009

Maximum Diversion Rate: 0.46 CFS

This is to certify, that OLIN HANNUM
2449 SOUTH 2300 WEST
WEST HAVEN ID 84401

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
IRRIGATION	04/01 to 10/31	0.46 CFS

LOCATION OF POINT(S) OF DIVERSION:GROUND WATER SE $\frac{1}{4}$ SE $\frac{1}{4}$ NE $\frac{1}{4}$ Sec. 27 Twp 15S Rge 36E, B.M. ONEIDA County**PLACE OF USE:** IRRIGATION

Twp	Rge	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
15S	36E	27			6.0	17.0													23.0

Total Acres: 23

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **January 01, 2013**.
2. Subject to all prior water rights.
3. After specific notification by the Department, the right holder shall install a suitable measuring device or shall enter into an agreement with the Department to use power records to determine the amount of water diverted and shall annually report the information to the Department.
4. The right holder shall install or construct a straight length of conduit or ditch suitable for installation of a device for measuring the entire flow of water being diverted in connection with this right. If the right holder uses conduit, the straight length of conduit shall be at least fifteen times the diameter of the conduit and shall be above ground or otherwise easily accessible.
5. This right when combined with all other rights shall provide no more than 0.02 cfs per acre nor more than 3.5 afa per acre at the field headgate for irrigation of the lands above.
6. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
7. Upon determination by the Director that the diversion and use of water under this right is injuring prior water rights, the Director may require reconstruction of the well used as a point of diversion for this right and/or limit withdrawals of water under this right to prevent injury.

State of Idaho
Department of Water Resources
Permit to Appropriate Water
NO. 15-07332

8. Project construction shall commence within one year from the date of permit issuance and shall proceed diligently to completion unless it can be shown to the satisfaction of the Director of the Department of Water Resources that delays were due to circumstances over which the permit holder had no control.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Boise, this 25th day of December, 2010.


for GARY SPACKMAN, Interim Director

