

Block, Darla

From: Cindy Espe [cindyеспе@hotmail.com]
Sent: Tuesday, November 30, 2010 5:14 PM
To: Block, Darla
Subject: FW: Johnson Meadows Beneficial Use application

Darla,

I have attached the information below from DEQ. Please let me know if this answers your questions or if you need more information.

Thank you,

Cindy Espe

Advanced Technology Surveying
P.O. Box 3457
Hayden, Idaho 83835

Office 208-772-2745
Fax 208-762-7731
Cell 208-818-9053

Subject: RE: Johnson Meadows
Date: Tue, 30 Nov 2010 17:04:51 -0700
From: Matthew.Plaisted@deq.idaho.gov
To: cindyеспе@hotmail.com
CC: jbarton@phd1.idaho.gov

Cindy,

The PWS number is ID1280320. As far as regulation: water systems do not become public (regulated) until they either have 15 connections or serve 25 people. So while the total build-out may be 20 connections, the system does not become regulated until there are 15 physical connections to the water system. Once they meet the requirements for regulation (15 connections or 25 people), the Johnson Meadows water system will be regulated by Panhandle Health District.

Thanks,

Matt Plaisted
Associate Engineer

Idaho Department of Environmental Quality
2110 Ironwood Parkway
Coeur d'Alene, ID 83814
Ph: 208-769-1422 Fax: 208-769-1404
Matthew.Plaisted@deq.idaho.gov

From: Cindy Espe [<mailto:cindyеспе@hotmail.com>]
Sent: Tuesday, November 30, 2010 3:24 PM
To: Matthew Plaisted
Subject: Johnson Meadows

Hi Matt,

I am submitting the beneficial use forms to IDWR and they are asking for documentation showing that the water system is being regulated by DEQ and that it has been issued a public water supply number.

Thanks

Cindy Espe

Advanced Technology Surveying
P.O. Box 3457
Hayden, Idaho 83835

Office 208-772-2745
Fax 208-762-7731
Cell 208-818-9053