

Nelson, Dan

From: Kristin M. Moore [kmoore@rockymountainenvironmental.com]
Sent: Tuesday, October 26, 2010 10:22 AM
To: Nelson, Dan
Subject: RE: Blue Indian Homeowners Association Water Bank Lease/Rental

Dan,

The pond was designed based on dimensions Blue Indian developers received from IDWR to use the domestic exemption: 90' diameter, 15' deep, with 3:1 side slopes.

Kristin

From: Nelson, Dan [mailto:Dan.Nelson@idwr.idaho.gov]
Sent: Monday, October 25, 2010 10:45 AM
To: Kristin Moore
Subject: Blue Indian Homeowners Association Water Bank Lease/Rental

Hello Kristin,

I can't remember if I asked you for this or not, so I thought I better follow-up on it. After I submitted my initial draft on the Water Bank Lease for the Blue Indian Homeowners Association to the bosses for review, they asked that I attain the dimensions of the pond that was going to be constructed. They wanted this information to ensure that the pond could be maintained with the domestic exemption of 0.04 cfs and 2,500 gpd. We cannot allow a water bank lease on a water use that may require a water right in the future, so I need to determine that this pond can be filled and maintained with the domestic exemption. If you have any questions please give me a call.

If I forgot to inform you of this earlier, I am really sorry, and thank you for getting this information for me.

Daniel A. Nelson

Staff Hydrologist

Planning Bureau

Idaho Department of Water Resources

Telephone # (208) 287-4856