

MEMO

TO: File 31-11735

FROM: CPadilla

DATE: November 10, 2010

RE: Licensing Review Memo

Time Line:

Application for Permit Received: 11/26/01

Permit Approved: 1/22/02

Proof of Beneficial Use Received: 12/12/02

Field Exam Conducted: 9/4/07

Conditioning

Comment	Water Permit Condition Report
Doesn't carry to license	046 Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code.
Confirmed at field exam, doesn't carry to license	X02 Stockwater use is for 1,000 range cattle.

POU Overlap Analysis: No overlaps

PD Summary:

Tag #	Location	Rights that Use PD	Uses
D0021439	NESE Sec. 21 13N40E	31-11735	Stockwater

Volume and Diversion Rate: The field examiner ~~X~~ recommended a volume of 14 af. I compared this to figures in the field examiner's handbook and came up with different figures:

1000 range cattle x 12 gpd/cow = 13.4 af (it's possible Nate was rounding, so I recommend licensing this for the actual amount in the field examiners handbook of 13.4 afa)

The diversion rate, per the field examiners handbook, is 0.22 cfs. This permit is limited by the capacity of the system of 0.05, which is also the amount of the permit.

Amendment Needed?: NO