

MEMORANDUM

TO: File
FROM: Monica Van Bussum
DATE: July 14, 2010
RE: Licensing 37-8837

This memo serves to document some of the decisions I made while licensing 37-8837.

Contacts: City of Hailey; current data matches permitted data

Source/POD: Permitted for 3 PODs in SWSESW Section 4; field exam found the 3 PODs were in NWSESW. Since they were in the same 40-acre tract and we are not required to license to the 10-acre tract, I licensed the PODs to the 40-acre tract to avoid an amendment. The other PODs were in the correct 10-acre tract, but for consistency, I licensed those to the 40-acre tract as well.

Water Use: Field exam confirmed these are in the City of Hailey delivery system. Licensed season of use as permitted.

Quantity: Permitted for 4.67 cfs. Per a memo from Pam Skaggs on page 23 in the 37-2698 water right backfile, 37-8837 was filed to get additional diversion from the City of Hailey system, primarily additional capacity of the new well, and any additional diversion of water will be limited to the new amount authorized under 37-8837. 4.67 cfs (2100 gpm) was the additional diversion rate under the new wells in Section 4. Per transfer 4508, 37-2698, 37-2699 and 37-7305 were limited to 7.18 cfs in the previous system. These new wells in Section 4 allowed a total diversion rate of 4.67 cfs, so I put in a limiting condition limiting all 4 rights to 11.75 cfs (7.18 cfs plus 4.67 cfs equals 11.75 cfs).

A measurement was not conducted at the time of the field exam on December 8, 2009, but one was not required.

POU: POU is the City of Hailey's large POU.

SCANNED
SEP 10 2010