

Marshall, Aaron

From: Kaufman, Joe
Sent: Friday, June 11, 2010 4:35 PM
To: Marshall, Aaron
Subject: SteveCo Canyon Pumps

Aaron,

As a follow up to our conversation this morning on the P Stevens or SteveCo pumps:

The Pumps in Canyon Creek have totalizing mechanical flow meters in both mainlines that were operating for the 2009 irrigation season. I verified the West Flow Meter on 8/13/2009 with a Fuji Acoustic Flow meter and found them to be in reasonable agreement. (Fuji = 2,049 gpm when the mechanical meter registered 2,300 gpm). While more than the 10% benchmark, it still is satisfactory to Water District 1. The last measurement for the East Flow Meter was 8/5/2008, although the record isn't clear exactly what the measurement was, it appears to have confirmed the mechanical flow meter as accurate.

Let me know if you need more information.

-Joe Kaufman