

MEMORANDUM

TO: Files 63-12416 and 63-31677

FROM: Monica Van Bussum

DATE: March 11, 2010

RE: Reinstatement of permit 63-31677; licensing of permits 63-12416 and 63-31677

This memo is to document the decision I made while licensing 63-12416 and 63-31677.

Contacts: Change of address completed.

Source: Field exam confirmed presence of multiple wells. Well #20-A is licensed under 63-12416 and 20-A and 20-B are both included under 63-31677. Because both wells are included in 63-31677, a combined use limit of 9.50 cfs is needed.

Purpose of use: As permitted

POD: Well 20-A is licensed under 63-12416 and 20-A and 20-B are both included under 63-31677. Three wells were originally permitted under 63-31677 but February 2010 conversation with Ed Squires of HydroLogic indicates third well was not developed.

POU: City of Meridian. Large POU identified.

Quantity: System capacity for 20-A was 4.5 cfs and for 20-B was 5 cfs for a total system capacity of 9.5 cfs between the two. Combined use limit needed because of 20-A being included on both rights.

Reinstatement of 63-31677: Proof was due in 2008 for 63-31677 but not submitted until December 22, 2009. Review of documents submitted by HydroLogic on behalf of City of Meridian indicate grounds for reinstatement. Advance in priority to December 22, 2009.

Conditions: Changed depth of water bearing zone for 63-12416 consistent with field examiner's suggestion. Removed outdated conditions from 63-12416. Added conditions describing wells, since both wells are housed in the same building. Added applicable large POU conditions.

63-12416 ← Note from Ed Squires requested substituting 496 to 996 for water bearing zone condition based on test well #20 (well log attached showing water bearing zone to 990 feet). Wrote order changing zone and included new zone in license.

