



P.O. Box 1005

Nampa, Idaho 83653

208-466-7376

July 21, 2009

Layne of Idaho has performed work on the Eagle Pines pump. We have measured and recorded static water levels at various times over the last 5 years.

August 13, 2004, static measured 120 ft.

June 17, 2005, static measured 120 ft.

July 25, 2006, static measured 124 ft.

Steve Cook

Layne of Idaho, Inc.