

RECOMMENDATION OF WATERMASTER

Application No: 74781, 74719, 74396
Water Right No:
Applicant Name: Alliance L&L, LaVel Stoker

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:

Include condition 201, and use modified condition 212 which indicates that irrigation and non-irrigation uses from the same well(s) will be required to be measured independently.


Otherwise, OK as drafted.

- c) ☐ I oppose approval of this application(s) for the following reasons:
- d) ☒ Additional comment:

Suspect that some or all of the wells used for irrigation may also be used at dairy or feedlot facilities. WD140 will require separate flow meters for each type of use from a single well.

Dated: September 23, 2009

Water District 140


Cindy J Yenter, Watermaster