

RECEIVED

MAR 12 2007

Permit No: 57-7593D

DEPARTMENT OF WATER RESOURCES

Page 1

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
BENEFICIAL USE FIELD REPORT

A. GENERAL INFORMATION

Permit No: 57-7593D

Exam Date: 8/16/2005

1. Current Owner: RON &/or SANDY KITCHELL
HC 79 BOX 308
MELBA ID 83641

Present Owner: DARIN &/or HANNAH REINERTSON
15442 WAR EAGLE RD
MURPHY ID 83650

2. Accompanied by: Jim Klevenberg

Phone No: 495-2771

Address: Eagle View Estates

Relationship to Permit Holder: Resident and manager of Association No. 1

3. SOURCE

TRIBUTARY

GROUND WATER

B. OVERLAP REVIEW

1. Other water rights with the same place of use: None

2. Other water rights with the same point of diversion: 57-11660, 57-7593B

C. DIVERSION AND DELIVERY SYSTEM

1. LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER

SE1/4SE1/4

Sec. 9, Twp 02S, Rge 02W, B.M.

OWYHEE County

Method of Determination: Exam, Arc View, Plat Map

2.

PLACE OF USE: DOMESTIC

Twp	Rge	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
02S	02W	9													X				

Method of Determination: Exam

3. N Delivery System Diagram Attached (required). Indicate all major components and distances between components. Indicate weir size/pipe as applicable.
- Y Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.
- Y Aerial Photo Attached (required for irrigation of 10+ acres).
- Y Photo of Diversion and System Attached

4.

<u>Well or Diversion ID No.*</u>	<u>Motor Make</u>	<u>Hp</u>	<u>Motor Serial No.</u>	<u>Pump Make</u>	<u>Pump Serial No. or Discharge Size</u>
Well #3	Franklin	5		Submersible	

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

<u>Measurement Equipment</u>	<u>Type</u>	<u>Make</u>	<u>Model No.</u>	<u>Serial No.</u>	<u>Size</u>	<u>Calib. Date</u>
Theoretical						

2. Measurements: Theoretical based on 70% efficiency

E. FLOW CALCULATIONS Additional Computation Sheets Attached

Measured Method:

Per well log: 210' static water level (assume 220' pumping water level)

Per well driller: pump on @ 60 psi, off @ 80 psi

220 PWL + 60 psi x 2.31 = 359 total dynamic head

Theoretical:.7 x 8.8 x 5 hp = .09 cfs pumping capacity

359 TDH

Ransom water wells drilled the well and Knie Pump and Drilling installed the pump. Mike Knie stated that the pump was a 5 hp 35 to 40 gpm pump. He could not remember the brand...either a Aermotor or Gould pump.

40 gpm = .09 cfs

F. VOLUME CALCULATIONS

1. Volume Calculations for Irrigation:

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 =$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} =$$

2. Volume Calculations for Other Uses:

Internal/external domestic use for 1 home = 1.2 afa

G. NARRATIVE/REMARKS/COMMENTS

A 6 inch well equipped with a 5 hp submersible pump, located in Lot 6, Block 2, supplies water to Lot 9, Block 1, Eagle View Estates Subdivision. The well also supplies water to rights 57-11660 (Lots 2 & 3 Block 3 & Lot 8, Block 1) and 57-7593B (Lot 10, Block 1).

The system consists of three 120 gallon pressure tanks, 4 inch mainline that reduces to 2 ½ inches, and 2 inch stub line to the home. The permit listed .02 cfs for internal domestic use and .10 cfs for irrigation of 5 acres. The subdivision covenant states that each lot is limited to irrigation of ½ acre. Less than ½ acre was found irrigated at the time of the exam. Rather than licensing the actual amount found, which was little or no irrigation, only domestic use was recommended. This allows yard irrigation up to ½ acre. The system capacity is .09 cfs. .04 cfs was recommended for licensing to account for internal and external domestic uses, which is within the parameters and intent of the permit, proof of beneficial use fee paid and system capacity.

The parent right for permit 57-7593B is 57-7593, which was split into 57-11660, 57-11661, 57-7393B and 57-7593D. All use the same well and system except 57-11661, which uses a separate well.

The current owners listed on the proof report have sold to the present owners listed on the proof report. A completed change in ownership has been included with this exam.

Permit 57-7593D was lapsed at the time of the exam, however, the new owners got it reinstated once they were aware of the situation and the process.

No other water rights are used. This right, when combined with 57-11660 and 57-7593B, is limited to the diversion capacity of .09 cfs.

Have conditions of permit approval been met? ☐ Yes ☐ No

H. RECOMMENDATIONS**1. Recommended Amounts**

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.040 CFS	1.20 AF
<u>Totals:</u>		0.040 CFS	1.20 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name Loi G. Gauer Date 2/26/07


Reviewer _____ Date _____



Idaho Department of Water Resources

57-7593D

02S 02W S9



-  POU
-  POD
-  Sections
-  Quarter/Quarter

300 0 300 Feet



IDWR
Prepared by: Lori Graves
Date: 02-26-07
2006 Photography


UNPLATTED

EAGLE VIEW ESTATES

PLAT SHOWING

SITUATED IN THE E 1/2 OF THE SE 1/4 OF
SECTION 9 AND THE S 1/2 OF
THE SW 1/4 OF SECTION 10 WESTERLY OF
HWM 78 T.25S., R.2W., B.1M.,
OWHEE CO., IDAHO

1995



NOTES

1. A PUBLIC UTILITY, DRAINAGE, AND IRRIGATION EASEMENT 10.00 FEET IN WIDTH IS HEREBY DEDICATED ADJACENT TO ALL LOTS.
2. A PRELIMINARY AND UTILITY EASEMENT 10.00 FEET IN WIDTH IS HEREBY DEDICATED ADJACENT TO ALL LOTS.
3. A 30' WIDE EASEMENT FOR THE CONVEYANCE OF WATER, GAS, AND ELECTRICITY IS HEREBY DEDICATED ADJACENT TO ALL LOTS.
4. LOT 1 AND LOT 2 ARE COMMUNITY WELL LOTS AND NOT FOR RESIDENTIAL BUILDINGS.

CURVE DATA

CURVE	DELTA	ARC	CHORD	AREA	PERCENT
1	90.00-00	20.00	20.00	1.57	5.31-31.57
2	90.00-00	20.00	20.00	1.57	5.31-31.57
3	90.00-00	20.00	20.00	1.57	5.31-31.57
4	90.00-00	20.00	20.00	1.57	5.31-31.57
5	90.00-00	20.00	20.00	1.57	5.31-31.57
6	90.00-00	20.00	20.00	1.57	5.31-31.57
7	90.00-00	20.00	20.00	1.57	5.31-31.57
8	90.00-00	20.00	20.00	1.57	5.31-31.57
9	90.00-00	20.00	20.00	1.57	5.31-31.57
10	90.00-00	20.00	20.00	1.57	5.31-31.57
11	90.00-00	20.00	20.00	1.57	5.31-31.57
12	90.00-00	20.00	20.00	1.57	5.31-31.57
13	90.00-00	20.00	20.00	1.57	5.31-31.57
14	90.00-00	20.00	20.00	1.57	5.31-31.57
15	90.00-00	20.00	20.00	1.57	5.31-31.57
16	90.00-00	20.00	20.00	1.57	5.31-31.57
17	90.00-00	20.00	20.00	1.57	5.31-31.57

LEGEND

- FOUND BRASS CAP MONUMENT
- SET 5/8" IRON PIN WITH PLASTIC CAP
- SET 1/2" X 24" IRON PIN WITH PLASTIC CAP
- BOUNDARY LINE
- LOT LINE
- CENTER LINE
- BLK 1
- LOT 1



LANDMARK SURVEYING



ART SCHULTZ ENGINEERING
CIVIL/STRUCTURAL CONSULTANT
1000 N. 10TH ST.
BOISE, IDAHO 83702
(208) 463-0505

BOOK PAGE SHEET 1 OF 2

1995

PROTECTIVE COVENANTS AND REGULATIONS

EAGLE VIEW ESTATES SUBDIVISION

DATED: OCTOBER 24, 1995

RECORDED: _____

DOCUMENT NO: _____

THE UNDERSIGNED, ALAN E. LINDNER & DEBRA S. LINDNER AND CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER, BEING THE OWNERS IN FEE SIMPLE OF THAT CERTAIN REAL ESTATE SITUATE IN OWYHEE COUNTY, STATE OF IDAHO, AND PARTICULARLY DESCRIBED AS FOLLOWS:

SITUATED IN THE E1/2 OF THE SE1/4 OF SECTION 9 AND A PORTION OF THE S1/2 OF THE SW1/4 OF SECTION 10 WESTERLY OF HWY 78 T.2 S., R.2 W., B.M., OWYHEE COUNTY, IDAHO

1. GENERAL PROVISIONS: GRANTORS HEREBY CERTIFY AND DECLARE THAT THEY HAVE ESTABLISHED, AND DO HEREBY ESTABLISH, A GENERAL PLAN FOR THE DEVELOPMENT, IMPROVEMENT, MAINTENANCE AND PROTECTION OF THE REAL PROPERTY EMBRACED IN EAGLE VIEW ESTATES SUBDIVISION, THE SAME BEING PART OF THE COUNTY OF OWYHEE, STATE OF IDAHO, AND HAVE ESTABLISHED AND DO HEREBY ESTABLISH, THESE PROTECTIVE REGULATIONS FOR THE BENEFIT OF ALL PERSONS WHO MAY HEREAFTER BECOME THE OWNERS OF LOTS IN SAID EAGLE VIEW ESTATES SUBDIVISION, ALL OF WHICH LOTS ARE HEREBY DECLARED TO BE SUBJECT TO THESE PROTECTIVE COVENANTS AND REGULATIONS WHICH ALL ATTACH TO AND RUN WITH THE LAND, AND EVERY PART AND PARCEL THEREOF AND SHALL BIND ALL PERSONS WHO MAY AT ANY TIME AND FROM TIME TO TIME, OWN SAID PROPERTY, OR ANY PART THEREOF AND THEIR RESPECTIVE PERSONAL REPRESENTATIVES, HEIRS OR SUCCESSORS IN INTEREST.

THESE PROTECTIVE REGULATIONS SHALL BE DEEMED TO BE FULLY AND SUFFICIENTLY DESCRIBED OR INCORPORATED INTO ANY INSTRUMENT OF CONVEYANCE BY DESIGNATING AND REFERRING TO THE SAME AS THE PROTECTIVE COVENANTS AND REGULATIONS OF EAGLE VIEW ESTATES SUBDIVISION.

THE "GRANTOR" HEREINAFTER USED IN THE REGULATION SHALL REFER TO ALAN E. LINDNER & DEBRA S. LINDNER, HUSBAND AND WIFE, AND CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER, HUSBAND AND WIFE. THE TERM "GRANTEE" HEREINAFTER USED SHALL REFER TO ANY PURCHASER OF A LOT IN EAGLE VIEW ESTATES SUBDIVISION, SAID PURCHASER'S SUCCESSORS IN INTEREST AND ASSIGNS.

2. TYPE OF STRUCTURE: A LOT SHALL CONSIST OF AN AREA OF FIVE (5) ACRES PLUS/MINUS 0.01 ACRES EXCEPT LOT #6 IN BLOCK 2 & LOT #9 IN BLOCK 3, WHICH ARE WELL LOTS AND ARE 2.05 ACRES AND 2.49 ACRES, RESPECTFULLY, CONTAINED ON THE OFFICIAL PLAT OF EAGLE VIEW ESTATES SUBDIVISION, AND SHALL NOT BE DIVIDED WITHOUT APPROVAL OF THE OWYHEE COUNTY COMMISSIONERS AND MEMBERS OF THE EAGLE VIEW ESTATES HOMEOWNERS ASSOCIATION. IT IS THE EXPRESS INTENTION IN THE CREATION OF EAGLE VIEW ESTATES SUBDIVISION FOR THE ACCOMMODATION OF RESIDENTIAL DWELLINGS OF A MINIMUM AREA OF 1000 SQUARE FEET. ALL BUILDINGS ERECTED UPON ANY LOT SHALL BE FINISHED, PAINTED AND MAINTAINED IN GOOD REPAIR SO AS TO BE INOFFENSIVE TO ANY OTHER PROPERTY OWNERS AND SHALL BE ON A FOUNDATION OF CONCRETE OR CEMENT BLOCKS.

CONSTRUCTION OR PLACEMENT OF ANY BUILDINGS SHALL BE PROSECUTED DILIGENTLY AND CONTINUOUSLY FROM THE TIME OF COMMENCEMENT THEREOF, AND THE SAME SHALL BE COMPLETED, WITHIN EIGHTEEN (18) MONTHS AFTER THE DATE OF COMMENCEMENT OF CONSTRUCTION UNLESS SUCH COMPLETION IS PREVENTED BY CAUSES BEYOND THE CONTROL OF THE GRANTEE, OR WITH THE APPROVAL OF THE ARCHITECTURAL CONTROL COMMITTEE. NO BUILDING SHALL BE ERECTED OR PLACED ON ANY LOT WITHOUT THE APPROVAL OF THE ARCHITECTURAL CONTROL COMMITTEE, WHICH CONSISTS OF THE

GRANTORS, AND ONE OTHER APPOINTED INDIVIDUAL FROM THE RESPECTIVE HOMEOWNER'S ASSOCIATIONS.

A TEMPORARY DWELLING MAY BE USED DURING THE EIGHTEEN (18) MONTH CONSTRUCTION PERIOD. TEMPORARY DWELLING MUST BE APPROVED BY THE ARCHITECTURAL CONTROL COMMITTEE.

3. BUILDING LOCATION: NO BUILDING SHALL BE LOCATED NEARER THAN TWENTY (20) FEET FROM THE FRONT LOT LINE, OR TEN (10) FEET FROM ANY SIDE LOT LINE. LOTS #6, #7 & #8 IN BLOCK 3 ARE RESTRICTED FROM CONSTRUCTION OF PERMANENT STRUCTURES WITHIN ONE HUNDRED (100) FEET OF THE CENTER OF THE DRAW ESTABLISHED BY NATURAL DRAINAGE, AND NO OBSTRUCTIONS MAY BE PLACED WITHIN SAID DRAINAGE WITHOUT APPROVAL FROM ARCHITECTURAL CONTROL COMMITTEE.

4. COMMERCIAL USE & HOME OCCUPATION: THE EAGLE VIEW ESTATES HOMEOWNER'S ASSOCIATION MUST APPROVE, IN ADVANCE OF SUCH USE, ANY COMMERCIAL USE OF A LOT LOCATED WITHIN THE SUBDIVISION.

5. EASEMENTS: ALL LOTS HAVE A TEN (10) FEET UTILITY EASEMENT AROUND PERIMETERS. LOTS #10 IN BLOCK 1, #1 IN BLOCK 2, & #1 IN BLOCK 3, ARE EFFECTED BY THE CULDESAC TO BE ESTABLISHED AT THE END OF EACH RESPECTIVE ROADWAY, AND THOSE CULDESACS WILL GRANT ACCESS TO BLM LAND.

6. ELECTRICAL SERVICES: ALL LOTS SHALL HAVE ELECTRICAL SERVICE TO THE PROPERTY LINE. IT WILL BE THE RESPONSIBILITY OF EACH GRANTEE TO INSTALL SERVICE TO THE REQUIRED LOCATION ON THE INDIVIDUAL LOT. GRANTOR SHALL BE RESPONSIBLE FOR THE COST OF INSTALLATION OF ELECTRICAL SERVICE TO THE PROPERTY LINE, AND GRANTEE SHALL BE RESPONSIBLE FOR THE COST OF FURTHER INSTALLATION ONTO THE LOT. ALL ELECTRICAL SERVICE SHALL BE INSTALLED UNDERGROUND.

7. WELLS AND WATER SYSTEMS: FOUR WELLS WILL BE ESTABLISHED FOR THE LOTS IN THE EAGLE VIEW ESTATES SUBDIVISION. EACH WELL WILL SERVE A MAXIMUM OF SIX LOTS FOR DOMESTIC USE, WHICH WILL INCLUDE IRRIGATION OF ONE HALF ACRE ONLY. A HOMEOWNER'S ASSOCIATION SHALL BE ESTABLISHED FOR EACH GROUP OF SIX LOTS. WELL LOTS SHALL BE DEDICATED TO EACH RESPECTIVE ASSOCIATION. WATER SYSTEM #1 WILL SERVE LOTS #1 THROUGH #6 IN BLOCK 1, WATER SYSTEM #2 SHALL SERVE LOTS #4 THROUGH #8 IN BLOCK 3, WATER SYSTEM #3 WILL SERVE LOTS #1 THROUGH #5 IN BLOCK 2 & LOT #1 IN BLOCK 3, AND WATER SYSTEM #4 WILL SERVE LOTS #7 THROUGH #10 IN BLOCK 1, LOTS #2 & #3 IN BLOCK 3. EACH WELL SYSTEM SHALL BE OWNED AND MAINTAINED BY THE MEMBERS OF THE HOMEOWNER'S ASSOCIATION THAT ARE USING THAT SYSTEM. A MONTHLY FEE SHALL BE PAID BY EACH MEMBER, AND THAT FEE SHALL BE USED TO PAY THE COST OF OPERATING THE PUMP, WITH THE REMAINDER OF THE FEES PUT INTO AN INTEREST BEARING CHECKING ACCOUNT TO BE USED FOR MAINTENANCE AND REPAIR OF EACH RESPECTIVE WATER SYSTEM. THE ASSOCIATION SHALL ELECT OFFICERS TO PERFORM THE NECESSARY DUTIES REQUIRED OF SUCH AN ASSOCIATION.

THE WELLS AND WATER SYSTEMS OF THE EAGLE VIEW ESTATES SUBDIVISION WILL MEET ALL REQUIREMENTS OF THE SOUTHWESTERN DISTRICT HEALTH DEPARTMENT.

THE COST OF WATER LINE INSTALLATION TO THE PROPERTY LINE WILL BE THE RESPONSIBILITY OF THE GRANTOR. GRANTEE SHALL BE RESPONSIBLE FOR THE COST OF FURTHER INSTALLATION ONTO THE INDIVIDUAL LOTS, AND THE COST OF MAINTENANCE AND REPAIR OF WATER LINES.

8. SEPTIC SYSTEMS: GRANTORS SHALL INSTALL, AT THEIR EXPENSE, A SEPTIC SYSTEM AT GRANTEE'S CHOICE OF LOCATION WITHIN COVENANTS GUIDELINES AND THE REGULATIONS AND LAWS OF THE STATE OF IDAHO. THE SEPTIC DISPOSAL SYSTEM SHALL BE INSTALLED BY A LICENSED PUBLIC CONTRACTOR ACCORDING TO SOUTHWESTERN DISTRICT HEALTH DEPARTMENT REQUIREMENTS. GRANTEE SHALL BE RESPONSIBLE FOR MAINTENANCE AND REPAIR OF THE SYSTEM AFTER INSTALLATION.

9. EXCAVATION: NO EXCAVATION FOR STONE, GRAVEL, EARTH OR MINERALS SHALL BE MADE UPON A BUILDING SITE, EXCEPT FOR EXCAVATION REQUIRED FOR THE CONSTRUCTION OF A BUILDING THEREON. NO OIL DRILLING, OR MINING OPERATIONS OF ANY KIND SHALL BE PERMITTED UPON OR IN ANY LOT.

10. ANIMALS: NO MORE THAN SIX HEAD OF LIVESTOCK PER LOT (INCLUDING CATTLE, HORSES, ETC.) AND ALL ANIMALS MUST BE PROPERLY CONTAINED ON EACH INDIVIDUAL LOT, AND CANNOT BE ALLOWED TO ANNOY OTHER PROPERTY OWNERS OR TRESPASS UPON THE PROPERTY OF OTHERS, INCLUDING SMALL DOMESTIC PETS, SUCH AS DOGS AND CATS.

11. ROADWAY MAINTENANCE: WAR EAGLE ROAD AND CINNABAR WAY WILL BE MAINTAINED BY THE HOMEOWNERS' ASSOCIATIONS.

ATTESTED:

ALAN E. LINDNER

DATED: _____

DEBRA S. LINDNER

DATED: _____

CHARLES S. HIGHTOWER

DATED: _____

VICKY L. HIGHTOWER

DATED: _____

ACKNOWLEDGEMENT

STATE OF IDAHO, COUNTY OF OWYHEE

On this day of OCTOBER 24, 1995, before me personally appeared;

ALAN E. LINDNER, DEBRA S. LINDNER, CHARLES S. HIGHTOWER & VICKY L. HIGHTOWER

known to me to be the persons whose names subscribed to the within instrument, and acknowledged to me that they executed the same.

IN WITNESS WHEREOF, I have set my hand and affixed my official seal the day and year in this certificate first above written.

Notary Public

Residence: _____

Comm. Expires: _____

IDAHO DEPARTMENT OF WATER RESOURCES

WELL INSPECTION FORM

1. DRILLING PERMIT NO: 763678 OTHER APPLICABLE NO: 57-11660
57-7593B,D
2. OWNER: Eagle View Estates Homeowner ^{Acres #3} Phone: 495-2912
Address: Attn: DEBRA CAMPBELL, 15577 War Eagle Rd
Murphy Id 83650
3. WELL LOCATION: Twp 22, Rge. 2W, Sec. 9, Se 1/4 Se 1/4
County Owyhee (Provide sketch map and photo on reverse.)
4. DRILLER: Ransom Lic. No. 575
When Drilled? replaced in 2000
5. WELL CONSTRUCTION:
Casing Diameter 6 inches Water tight cap? ☒ Yes ☐ No Access Port: ☐ Yes ☒ No
Casing $\geq$ 12 inches above ground? ☒ Yes ☐ No - Describe _____
Depth of Casing 247 ft. Method Drilled air rotary/cable
Condition of Well Casing: ☒ Good ☐ Fair ☐ Poor Describe _____
Control Valve? ☐ Yes ☒ No Pressure Gauge: ☒ Yes ☐ No
Condition of Piping and Valving OK
Auger to a depth of _____ ft. Evidence of Annular Seal ☐ Yes ☐ No
Are there obvious construction problems that may be a source for contamination or waste of water?
☐ Yes ☒ No (Describe in Remarks and Attach Photo - On Reverse)
6. HYDROLOGIC INFORMATION:
Depth to Static Water 210 ft. Water Temperature cold °F
Flowing Artesian ☐ Yes ☒ No Pressure: 60-80 (psi)
Water Sample Taken? ☐ Yes ☒ No If yes, describe purpose _____
Water Quality Measurements/Observations (Describe) _____
7. WELL USE: multiple
☒ Domestic ☐ Irrigation ☐ Stock
☐ Test ☐ Municipal ☐ Industrial
☐ Abandoned ☐ Waste Disposal/Injection ☐ Not Used
☐ Other: _____

8. POSSIBLE CONTAMINATION SOURCES:

Is there evidence of Chemigation? ☐ Yes ☒ No

If yes, is there a check-valve present? ☐ Yes ☐ No

Is there a possible source of contamination nearby? ☐ Yes ☐ No

If yes, what Type? _____

How far away from the well is this source? _____

9. REMARKS:

This well appears to have replaced
57-97-C-0007-000

Don Garrow

Signature of Dept. Representative & Title

8/16/05

Inspection Date

PHOTOS, DRAWINGS, OTHER ATTACHMENTS:

Printed 03/21/2000
Ident No. 763678
Water Right Number: 57-7593B,C,D

STATE OF IDAHO
DEPARTMENT OF WATER RESOURCES
DRILLING PERMIT

Relationship: Owner/Operator
Name: CHARLES HIGHTOWER
Address: HC 79 BOX 34X
MELBA ID 83641

Relationship: Owner/Operator
Name: VICKY HIGHTOWER
Address: HC 79 BOX 34X
MELBA ID 83641

Relationship: Owner/Operator
Name: ALAN LINDER
Address: HC 79 BOX 34X
MELBA ID 83641

Relationship: Owner/Operator
Name: DEBRA LINDNER
Address: HC 79 BOX 34X
MELBA ID 83641

Proposed Well Location: Township 02S, Range 02W, Section 9, SE, SE
OWYHEE County

Street Address of Well Site: Hwy 78 1/2 mile past MM 20 Toward Murphy
MURPHY ID

Lot, Block, and Subdivision: Lot 16, Block 2, Subdivision Eagle View Estates
Proposed Use of Well: Multiple Residence, Irrigation

Well Construction Information:

- A. Replacement
- B. Proposed Surface Diameter: 6 inches. Proposed Maximum Depth 275 Feet
- C. Anticipated Bottom Hole Temperature: 85F and less

Construction Start Date: 03/22/2000

Anticipated Well Drilling Company:

RANSOM WATER WELLS (No. 575)

Applicant's Signature: _____

Title: _____

Representative

Date

3/21/00

Supervisor or Operator W. J. [Signature] Date 8-15-97

57-7593D



Pump House System & Well
Located in the SESE S9 T2S R2W
AKA Lot 6, Block 2



57-7593D



P/U: T2S R2W S9 NESE
AKA Lot 9, Block1
Eagle View Estates Subdivision