

State of Idaho
Department of Water Resources
Permit to Appropriate Water

NO. 96-09435

Priority: July 18, 2008

Maximum Diversion Rate: 0.20 CFS

This is to certify, that BAKER EXEMPT TRUST
8216 LANKERSHIM BLVD #3
NORTH HOLLYWOOD CA 91603
(208)264-5602

has applied for a permit to appropriate water from:

Source: PEND OREILLE LAKE

Tributary: PEND OREILLE RIVER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>
IRRIGATION	04/01 to 10/31	0.05 CFS
FIRE PROTECTION	01/01 to 12/31	0.20 CFS

LOCATION OF POINT(S) OF DIVERSION:

PEND OREILLE LAKE L7 (SW1/4SE1/4) Sec. 1, Twp 56N, Rge 01E, B.M. BONNER County

PEND OREILLE LAKE L7 (SW1/4SE1/4) Sec. 1, Twp 56N, Rge 01E, B.M. BONNER County

PLACE OF USE: IRRIGATION and FIRE PROTECTION


Twp Rge Sec	NE				NW				SW				SE				Totals
	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
56N 01E 1															1.5	.3	1.8
															L7		
															X	X	
															L7		

Total Acres: 1.75

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **September 01, 2010**.
2. Subject to all prior water rights.
3. Water shall not be diverted for fire protection use under this right except to fight or repel an existing fire.
4. This right when combined with all other rights shall provide no more than 0.03 cfs per acre nor more than 3.0 afa per acre at the field headgate for irrigation of the lands above.
5. This right does not grant any right-of-way or easement across the land of another.
6. A fish screen of 1/4 inch or smaller mesh shall be installed and maintained at the point of diversion.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Coeur d'Alene, this 15th day of September, 2009.


GARY SPACKMAN, Interim Director