

State of Idaho
Department of Water Resources

RECOMMENDATION OF WATERMASTER

Application No: 45-14183
Water Right No:
Applicant Name: Southwest Irrigation District

Watermaster's Recommendation:

- a) ☐ I do not oppose approval of this application
- b) ☒ I do not oppose approval of this application if it is conditioned as follows:

Approval of this permit does not authorize irrigation of new lands.

Mitigation of this water right shall be accomplished by the non-use of ground water, under a valid water right, on lands to which waste water is delivered.

Right is under the jurisdiction of Water District 140.

Totalizing measuring devices required on both the pond inlet and the re-distribution pumps. Total diversions shall not exceed the volume of waste water received at the pond inlet.

Include standard waste water condition language.

- c) ☐ I oppose approval of this application(s) for the following reasons:
- d) ☒ Additional comment:

Dated: May 8, 2009

Water District 140



Cindy J Yenter, Watermaster