

Edl, Michele

From: Doug Self [pzdriggs@pdt.net]
Sent: Friday, January 09, 2009 2:43 PM
To: Edl, Michele; Kristin Moore
Cc: Mayor Lou Christensen
Subject: Re: status City of Driggs permits

Kristin / Michele -

Just wanted to let you both know that our Public Works Director, Jared Gunderson, will be taking time / date stamped photos of the High School Well meter on Saturday (he knows he needs to somehow also show identification of the meter as the High School meter) and we will e-mail this information to you on Monday. I understand we have a deadline on Monday to get this info to IDWR (is that end of day?).

Thanks for your patience. Jared has been out plowing late every night and is trying his best to get the information needed as fast as he can.

Best regards,
-Doug

Doug Self
Planning and Zoning Administrator
City of Driggs
PO Box 48, Driggs Idaho 83422
Ph: (208) 354-2362 Fax: (208) 354-8522
Web address: www.driggs.govoffice.com

Edl, Michele wrote:

Doug, Jared,
This email is to provide you a quick update on my progress.
I have reviewed the documentation that you sent me supporting beneficial use from the two City of Driggs wells: the High School well (permit 22-7790) and the Lions Park well (permit 22-7698). And I have made a stab at processing permit 22-7698.

Unfortunately, I am not able to make a theoretical calculation of the Lions Park flow match the available pump and well data. Either the pump horsepower is incorrect or pump level is incorrect or the flow rate is incorrect. The pieces just don't fit together.

Therefore, please re-contact your pump supplier and ask for the pump make, model, horsepower and pump performance curves for the submersible pump that the city had installed in the Lions Park well. Have them fax that information to me at 208-287-6700.

Sincerely
Michele Edl
Associate Engineer
Idaho Department of Water Resources
322 East Front Street
Boise ID 83720-0098
Office 208-287-4946
FAX 208-287-6700

1/9/2009