



State of Idaho

DEPARTMENT OF WATER RESOURCES

322 East Front Street • P.O. Box 83720 • Boise, Idaho 83720-0098

Phone: (208) 287-4800 • Fax: (208) 287-6700 • Web Site: www.idwr.idaho.gov

June 3, 2009

C. L. "BUTCH" OTTER
Governor

DAVID R. TUTHILL, JR.
Director

C/O ROBERT HEINTZ
NEBELS ADDITION WATER & SEWER ASSN
PO BOX 304
WORLEY ID 83876

RE: Lapsed Permit 95-8976

Dear Mr. Heintz:

Idaho Department of Water Resources (IDWR) has received the additional information that you submitted in April in order for us to continue the review of reinstating your lapsed permit. At this time I would like to thank you for submitting the additional information and give you a synopsis of my findings.

A review of Department of Environmental Quality's (DEQ) water supply sanitary survey reports conducted in 1999 indicate a system capacity of 33 gallons per minute or 0.07 cubic feet per second with a total of 6 connections on the system. DEQ's certificate of approval for this subdivision states that as of 1999 there were 7 lots already on the system with the permission to add 28 more lots.

Once a determination of beneficial use has taken place, the next step in the water appropriation process is to graduate the permit to a licensed status. This is the final step in the appropriation process.

In order for IDWR to reinstate the lapsed permit and issue a license, we need to evaluate and make a solid determination of the capacity of the system at the time proof of beneficial use was due and the number of lots that were stubbed-in to the system at the time proof of beneficial use was due. I believe that we have satisfied the first criteria for reinstating and licensing your permit however, the documentation that you submitted does not provide solid proof of the amount of lots stubbed-in to the system.

Acceptable proof should include an "AS-BUILT" map that is signed and certified by a professional engineer or DEQ reports that detail the system "AS-BUILT".

I will hold any action on your lapsed permit for 60 days to give you time to collect the information that I am requesting. Please don't hesitate to contact me at (208) 287-4944 if you have any questions regarding this letter.

Sincerely,

Cherie Padilla
Water Resource Agent
Water Allocation Bureau