

Edl, Michele

From: Edl, Michele
Sent: Tuesday, October 21, 2008 5:00 PM
To: 'Doug Self'; 'Jared Gunderson'
Cc: 'Kristin Moore'; 'Jason Linford, P.E.'; Arave, Nathaniel
Subject: RE: status City of Driggs permits

Doug, Jared,

This email is to provide you a quick update on my progress.

I have reviewed the documentation that you sent me supporting beneficial use from the two City of Driggs wells: the High School well (permit 22-7790) and the Lions Park well (permit 22-7698). And I have made a stab at processing permit 22-7698.

Unfortunately, I am not able to make a theoretical calculation of the Lions Park flow match the available pump and well data. Either the pump horsepower is incorrect or pump level is incorrect or the flow rate is incorrect. The pieces just don't fit together.

Therefore, please re-contact your pump supplier and ask for the pump make, model, horsepower and pump performance curves for the submersible pump that the city had installed in the Lions Park well. Have them fax that information to me at 208-287-6700.

Sincerely
Michele Edl
Associate Engineer
Idaho Department of Water Resources
322 East Front Street
Boise ID 83720-0098
Office 208-287-4946
FAX 208-287-6700

10/29/2008