

Hemenway, Sandy

From: Yenter, Cindy
Sent: Thursday, May 21, 2009 8:04 AM
To: Hemenway, Sandy
Subject: RE: Licensing of permit 36-8763 for the City of Paul

Sandy -

Totalizing meters are required on all municipal wells in the ESPA. Which well are we talking about, and what year was the BU exam? All three of Paul's wells have flowmeters installed according to my records.

Cindy

From: Hemenway, Sandy
Sent: Thursday, May 21, 2009 5:11 AM
To: Yenter, Cindy
Subject: FW: Licensing of permit 36-8763 for the City of Paul

Hi Cindy,

I'm working on the License for the City of Paul, and have completed the review. In the field inspection, they were able to conduct a measurement on the system, but due to limited space, one of the conditions seems to have not been met (installing and maintaining a totalizing meter requirement). Do you feel that this meter is needed?

Thanks,
Sandy

From: Keen, Shelley
Sent: Wednesday, May 20, 2009 5:21 PM
To: Merritt, Allen
Cc: Hemenway, Sandy; Peppersack, Jeff; Spackman, Gary
Subject: RE: Licensing of permit 36-8763 for the City of Paul

Allen,

Sandy is working on the license. I think she's almost done. The only issue seems to be non-compliance with the totalizing meter requirement in the permit. I asked her to talk with Cindy about whether its needed. If not, we can issue an order waiving the requirement. Otherwise, the city may need to comply first.

Shelley

From: Merritt, Allen
Sent: Wednesday, May 20, 2009 4:58 PM
To: Keen, Shelley
Cc: Peppersack, Jeff; Spackman, Gary
Subject: Licensing of permit 36-8763 for the City of Paul

Shelley,

As you may know I attended the "Capitol for a Day" in Paul today.

At that meeting I was approached by Representative Bert Stevenson inquiring about the City of Paul's getting their permit licensed. Apparently the mayor of the city was asking Mr. Stevenson for some help since apparently they have inquired at the state office already or some time ago and the license has not been issued. I told Mr. Stevenson that I did not know of any specific issue why the license was not being issued or if there was a specific problem other than the fact that most IDWR work effort is being focused on processing transfers with licensing being backlogged for the time being. Mr. Stevenson indicated that he would contact the state office directly.

I thought you might want to know since you will likely be responding to the inquiry.

Allen