

Weaver, Mathew

From: Weaver, Mathew
Sent: Friday, April 24, 2009 1:14 PM
To: Keen, Shelley
Cc: 'rharris@holdenlegal.com'
Subject: Permit 23-11387 Stream Flow Depletion Analysis Review

Attachments: 23-11387 Stm Dep Analysis.pdf

Shelly,

At your request I have reviewed the Engineer's Report submitted for permit 23-11387. I have prepared a memo for the file summarizing my finding and recommendations. In short I recommend the approval of the Engineer's Report with the addition of language that address the following: (1) inclusion of minimum perforation specifications for the concrete well casing; and (2) inclusion of a minimum depth to the top of the pump from the irrigation seasonal low water table elevation. Furthermore, I recommend that IDWR provide written approval to the permit holder and Mr. Harris in whatever form you feel prudent so that they may begin with their improvements.

I would be happy to issue such notification but would require a little guidance on your part as to what should be provided and how it should look.

Let me know if you have any questions.

Mat Weaver, PE
Staff Engineer
Idaho Department of Water Resource
(208) 287-4914



23-11387 Stm Dep
Analysis.pdf ...