

**Weaver, Mathew**

---

**From:** Rob Harris [rharris@holdenlegal.com]  
**Sent:** Tuesday, April 28, 2009 9:37 AM  
**To:** Weaver, Mathew  
**Cc:** Keen, Shelley  
**Subject:** RE: Permit 23-11387 Stream Flow Depletion Analysis Review  
**Attachments:** \_0427132740\_001.pdf; \_0427132740\_001.pdf

Mathew:

I realized I attached the wrong report. Here is the correct one.

<<...>>

Thanks,

Robert L. Harris

Holden, Kidwell, Hahn & Crapo, PLLC

1000 Riverwalk Drive, Suite 200

P.O. Box 50130

Idaho Falls, ID 83405-0130

Phone: (208) 523-0620

Fax: (208) 523-9518

E-Mail: [rharris@holdenlegal.com](mailto:rharris@holdenlegal.com)

**Confidentiality Notice:** The information contained in this electronic e-mail and any accompanying attachments, all of which may be confidential and/or privileged, is intended only for use by the person or entity to whom it is addressed. If you are not the intended recipient, any unauthorized use, disclosure or copying of this e-mail and its contents is strictly prohibited and may be unlawful. If you are not the intended recipient, please immediately notify the sender by return e-mail and delete the original message and all copies from your system. Thank you.

**Internal Revenue Service Circular 230 Disclosure:** Please note that any discussion of or advice regarding United States tax matters contained herein (including any attachments hereto) does not meet the requirements necessary to be a "covered opinion" as defined in Internal Revenue Service Circular 230, and therefore, is not intended or written to be relied upon or used and can not be relied upon or used for the purpose of avoiding federal tax penalties that may be imposed or for the purpose of promoting, marketing, or recommending any tax-related matters or advice to another party.

**From:** Weaver, Mathew [<mailto:Mathew.Weaver@idwr.idaho.gov>]  
**Sent:** Friday, April 24, 2009 1:14 PM  
**To:** Keen, Shelley  
**Cc:** rharris@holdenlegal.com  
**Subject:** Permit 23-11387 Stream Flow Depletion Analysis Review

4/28/2009

Shelly,

At your request I have reviewed the Engineer's Report submitted for permit 23-11387. I have prepared a memo for the file summarizing my finding and recommendations. In short I recommend the approval of the Engineer's Report with the addition of language that address the following: (1) inclusion of minimum perforation specifications for the concrete well casing; and (2) inclusion of a minimum depth to the top of the pump form the irrigation seasonal low water table elevation. Furthermore, I recommend that IDWR provide written approval to the permit holder and Mr. Harris in whatever form you feel prudent so that they may begin with their improvements.

I would be happy to issue such notification but would require a little guidance on your part as to what should be provided and how it should look.

Let me know if you have any questions.

**Mat Weaver, PE**  
**Staff Engineer**  
**Idaho Department of Water Resource**  
**(208) 287-4914**

<<23-11387 Stm Dep Analysis.pdf>>

.

!DSPAM:1090,49f20fd612265416998008! <<...>>

4/28/2009