

State of Idaho
Department of Water Resources

Permit to Appropriate Water

NO. 47-17127

Priority: May 19, 2004

Maximum Diversion Rate: 0.04 CFS

This is to certify, that NICK NIEFFENEGGER
P.O. BOX 793
SODA SPRINGS CA 95728

has applied for a permit to appropriate water from:

Source: GROUND WATER

and a permit is APPROVED for development of water as follows:

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>RATE OF DIVERSION</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.04 CFS	

LOCATION OF POINT(S) OF DIVERSION:

GROUND WATER L3 (SE1/4NW1/4NW1/4) Sec. 4, Twp 09S, Rge 14E, B.M.
TWIN FALLS County

PLACE OF USE: DOMESTIC

Twp	Rge	Sec	NE				NW				SW				SE				Totals
			NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	NE	NW	SW	SE	
09S	14E	4						X											
								L 3											

CONDITIONS OF APPROVAL

1. Proof of application of water to beneficial use shall be submitted on or before **March 01, 2014**.
2. Subject to all prior water rights.
3. Domestic use is for 1 home and does not include lawn, garden, landscape, or other types of irrigation.
4. Domestic use may include heating of 1 house and ancillary buildings as long as all water used for heating is maintained in a closed system (not open to air or contamination) and returned/injected into the same source aquifer at similar pressure and depth. This may be accomplished by injection of spent water in the source well or separate injection well.
5. Injection of spent heating water when discharged to a subsurface system must be authorized by a separate injection well permit. A prospectus of the injection plan shall be reviewed and approved by IDWR during the injection well permitting process.

State of Idaho
Department of Water Resources

Permit to Appropriate Water

NO. 47-17127

6. The right holder shall install and maintain a measuring device, pressure gauge and spigot in a straight length of conduit suitable to allow measurement of the entire flow of water being diverted, the pressure and temperature. Additionally the right holder shall install and maintain a separate measuring device, pressure gauge and spigot in a straight length of conduit suitable to measure the entire flow of water being injected, the pressure and temperature in connection with this right. The straight length of conduit shall be a least ten times the diameter of the conduit and shall be above ground or otherwise easily accessible.
7. The right holder shall routinely monitor and record the volumes of water diverted and water injected, the supply and return temperatures and the wellhead pressures on a monthly basis for two years. These records shall be provided to IDWR upon request.
8. This right and all other rights used for domestic purpose in connection to the household being served are limited to a combined total of 13,000 gallons per day.
9. Right holder shall comply with the drilling permit requirements of Section 42-235, Idaho Code and applicable Well Construction Rules of the Department.
10. Any license issued by IDWR pursuant to the right or portion thereof for the use of trust water is subject to a term review of 20 years after the date of this approval to determine availability of water for the use and to re-evaluate the public interest at the end of the term.

This permit is issued pursuant to the provisions of Section 42-204, Idaho Code. Witness the signature of the Director, affixed at Boise, this 11th day of March, 2009.



DAVID R. TUTHILL, JR., Director