

Comment Report

23-7062

1. DUNN1 2/21/1994 COPIED FROM REMARKS

Comment: SOURCE KNOWN LOCALLY AS BAGLEY SPRING. WATER USED ON CLAIMANTS PROPERTY AND USFS PROPERTY.

2. THOMPSON 8/22/1994 ADDRESS

Comment: CHANGE IN ADDRESS FROM JERRY BAGLEY 8/22/94/JT

4. narave 1/16/2009 overlap review

Comment: The place of use of this water right overlaps with 23-10263

5. kwalker 3/3/2004 STATUS

Comment: This permit was partially decreed in SRBA with condition A01 attached. In order to correct our records I have changed the decree status to draft license and opened up the closed permit record. A field examination needs to be completed and sent to state office so we can finalize this record.

6. jlarsen 8/31/2007 Field Report Narrative

Comment: At the spring the system has a 24 inch concrete culvert stuck on end as a capture device. This culvert diverts water into a 1 inch poly pipe which runs down hill. About 100 feet down hill the poly pipe tees, one line for domestic and one line for stockwater. About 5 feet east of the tee is around a 300 gallon holding tank that has a 5 HP pump to pump water uphill to the cabin. The stock troughs are about 100 feet down hill from the tee. There are two troughs in series, one about 200 gallons and the second is about 300 gallons. These troughs sit in the middle of a set of corrals.

SCANNED

JAN 23 2009

[illegible]