

[illegible]

Method of Determination:

3. N/A Delivery System Diagram Attached (required). Indicate all major components and distances between components. Indicate weir size/pipe as applicable.
- ☒ Map Attached Showing Location(s) of point(s) of diversion and place(s) of use (required). Scale must be 1:24,000 or greater.
- ☒ Aerial Photo Attached (required for irrigation of 10+ acres).
- N/A Photo of Diversion and System Attached

4.

<u>Well or Diversion</u>					
<u>ID No.*</u>	<u>Motor Make</u>	<u>Hp</u>	<u>Motor Serial No.</u>	<u>Pump Make</u>	<u>Pump Serial No. or Discharge Size</u>
<u>96-89-N-6</u>					

*Code to correspond with No. on map and aerial photo

D. FLOW MEASUREMENTS

1.

<u>Measurement Equipment</u>	<u>Type</u>	<u>Make</u>	<u>Model No.</u>	<u>Serial No.</u>	<u>Size</u>	<u>Calib. Date</u>

2. Measurements:

E. FLOW CALCULATIONS

____ Additional Computation Sheets Attached

Measured Method:

I USED THE DRILLER'S REPORT FOR THE FLOW CALCULATIONS. THE REPORT TESTED THIS WELL AT 12 GPM OR 0.03 CFS.

F. VOLUME CALCULATIONS**1. Volume Calculations for Irrigation:**

$$V_{I.R.} = (\text{Acres Irrigated}) \times (\text{Irrigation Requirement}) =$$

$$V_{D.R.} = [\text{Diversion Rate (cfs)}] \times (\text{Days in Irrigation season}) \times 1.9835 =$$

$$V = \text{Smaller of } V_{I.R.} \text{ and } V_{D.R.} =$$

2. Volume Calculations for Other Uses: DOMESTIC WITH 1/2 AC IRRIGATION = 1.2 AF

G. NARRATIVE/REMARKS/COMMENTS: This report was completed in office exempted proof beneficial use. The diversion rate for the water right is derived from the driller's report not from pump size.

Have conditions of permit approval been met? ☒ Yes ☐ No

H. RECOMMENDATIONS**1. Recommended Amounts**

<u>BENEFICIAL USE</u>	<u>PERIOD OF USE</u>	<u>DIVERSION RATE</u>	<u>ANNUAL VOLUME</u>
DOMESTIC	01/01 to 12/31	0.030 CFS	1.20 AF
<u>Totals:</u>		0.030 CFS	1.20 AF

2. Recommended Amendments

☐ Change P.D. as reflected above ☐ Add P.D. as reflected above ☒ None

☐ Change P.U. as reflected above ☐ Add P.U. as reflected above ☐ Other

I. AUTHENTICATION

Field Examiner's Name

Eric J. Quinn

Date

12-9-08

Reviewer

Eric J. Quinn

Date

12/31/8

96-9345



Legend

- ⊙ Right POD
-  Right POU

0 80 160 320 480 640 Feet

